

**SHUT DOWNS ON 132KV TRANSMISSION LINES / GRID STATIONS  
I.R.O GSO CIRCLE MEPCO SAHIWAL FOR 09/2024 (Area Affect)**

| Sr. No. | Disco | Name of Grid Station / Name of Equipment                                | Date     | Day       | Time |       | Purpose of Shut Down                                       | Affected Area   | Safety Supervisor                            |
|---------|-------|---|----------|-----------|------|-------|--|---|--|
|         |       |   |          |           | From | To    |  |   |  |
| 1       | MEPCO | 132KV Qadirabad/ 132/11KV 20/26MVA P/TF T-1                             | 05.09.24 | Thursday  | 8:00 | 14:00 | Annual maintenance / testing                               | 11KV O/G Hafiz Dain, Chak 73/4-R, Asia Poultry Feeds, Qadir Abad, Chak 46/5-L, (05-Feeders)   | Muhammad Akram Foreman, Cell # 0319-9765770  |
| 2       | MEPCO | 132KV Vehari/ 132KV CB VRI-1-BRW4 controlling 132KV Vehari-Burewala T/L | 06.09.24 | Friday    | 8:00 | 11:00 | Annual maintenance of 132KV C B VRI-1 and Isolator No. 101 | No area will be affected due to dual source. Only 30-40 MW load shed will be required from 132KV G/S Burewala, Burewala Old and Sahuka  | Abdul Rahman (AEM Vehari) 0319-9765644       |
| 3       | MEPCO | 132KV Sheikh F azal/ 132/11KV, 20/26MVA P/TF T-3                        | 09.09.24 | Monday    | 8:30 | 14:30 | Annual maintenance / testing                               | 11KV O/G Sultan, Zafar Shaheed, Fareed, New Firdous feeders (04-Feeders)  | Muhammad Akram Foreman Cell # 0319-9765770   |
| 4       | MEPCO | 132KV Jehanian/ 132/11KV 31.5/40 MVA P/TF T-1                           | 09.09.24 | Monday    | 8:00 | 14:00 | Annual Maintenance/testing                                 | 11 KV O/G Makhdoom Rasheed, Tibba Sultan pur No. 2, Ali Sherwan, Multani Wala, New Colony Jehanian feeders  | Abdul Rahman (AEM Vehari) 0319-9765644       |
| 5       | MEPCO | 132KV Sahiwal Old/ 132/11KV 31.5/40MVA P/TF T-1                         | 10.09.24 | Tuesday   | 8:00 | 15:00 | Annual maintenance / testing                               | 11KV O/G Royal Palm, Kasmeer Adibal, Lather Co-Ordinator, M A Foods, City-1, Arif Road, Boch Dhakoo, Khuja Arif, Multan Road, P.G H.S. Industrial Estate, Civil Line, Aiywa City-I, Aiywa City-II, Aiywa City-III Sohni Dharti, (16-No Feeders) | Muhammad Akram Foreman Cell # 0319-9765770   |
| 6       | MEPCO | 132KV Hasil Pur/ 132/66KV 31.5/40 MVA P/TF T-1                          | 10.09.24 | Tuesday   | 8:00 | 14:00 | Annual Maintenance/testing                                 | Whole area of 66KV Grid Station Bukhsan Khan and Chishtian (11KV O/G Madrassa, Main Bazar, Park, Guishan, City-I Bukhsan Khan, Syadan Wala & City-II Bukhsan Khan feeders)  | Abdul Rahman (AEM Vehari) 0319-9765644       |
| 7       | MEPCO | 66KV Hasil Pur-Chishtian T/L controlled by 66KV CB HSP-5 -CHN-1         | 10.09.24 | Tuesday   | 8:00 | 14:00 | Washing/cleaning of disc insulators                        | Whole area of 66KV Grid Station Bukhsan Khan and Chishtian (11 KV O/G Madrassa, Main Bazar, Park, Guishan, City-I Bukhsan Khan, Syadan Wala & City-II Bukhsan Khan feeders)   | Fazal Ur Rehman (AET Hasil Pur) 0319-9765642 |
| 8       | MEPCO | 132KV Head Sidhmal / 132/11KV 20/26MVA P/TF T-1                         | 11.09.24 | Wednesday | 9:00 | 15:00 | Annual maintenance / testing                               | 11KV O/G Sarey Sidhu, Rehman Garh, City, Abdul Hakeem, Mamro Sher, (04-Feeders)   | Muhammad Akram Foreman Cell # 0319-9765770   |
| 9       | MEPCO | 132KV Bahawal Nagar/ 132/11KV 31.5/40MVA P/TF T-1                       | 11.09.24 | Wednesday | 8:30 | 15:30 | Annual Maintenance/testing                                 | 11 KV O/G QT Mill, Scarp-D, City, Din Pur Shareef, Nizam Pura and Malik Pura feeders  | Abdul Rahman (AEM Vehari) 0319-9765644       |
| 10      | MEPCO | 132KV Sahiwal New / 132/11KV 20/26MVA P/TF T-3                          | 12.09.24 | Thursday  | 8:00 | 14:00 | Annual maintenance / testing                               | 11KV O/G Medhrali Sharif, Bilal Colony, Chak 81/5-R, 65, Yarey Wala (04- Feeders)   | Muhammad Akram Foreman Cell # 0319-9765770   |
| 11      | MEPCO | 132KV Mirchin Abad/ 132/11KV 20/26MVA P/TF T-1                          | 12.09.24 | Thursday  | 7:00 | 13:00 | Annual Maintenance/testing                                 | 11 KV O/G Fidal Shah, City and Farooq Shaheed feeders   | Abdul Rahman (AEM Vehari) 0319-9765644       |

*P-01*

| Sr. No. | Disco | Name of Grid Station / Name of Equipment                           | Date     | Day       | Time |       | Purpose of Shut Down                | Effected Area   | Safety Supervisor                          |
|---------|-------|--|----------|-----------|------|-------|-------------------------------------|---|--|
|         |       |  |          |           | From | To    |                                     |   |  |
| 12      | MEPCO | 132KV Chichawatri/132/11KV 31.5/40MVA P/TF T-2                     | 14.09.23 | Saturday  | 8:30 | 14:30 | Annual maintenance / testing        | 11KV O/G Chichawatri Old, Adeeb Shahed, City, Firdous, Hazoor Abad, Raj Kot, Muhammad Abad, T.H.Q Chichawatri & Imtiaz Textile Mill (09-Feeders)  | Muhammad Akram Foreman Cell # 0319-9765770 |
| 13      | MEPCO | 132KV Khair Pur Tomewalli/ 132/11KV 20/26 MVA P/TF T-1             | 16.09.24 | Monday    | 8:00 | 14:00 | Annual Maintenance/testing          | 11 KV O/G City Khair Pur, Israni, Tubewell, Goth Miltha, Kabira Pully and Jhok Sathu feeders  | Abdul Rahman (AEM Vehari) 0319-9765644     |
| 14      | MEPCO | 132KV Noor Pur/ 132/11KV 10/13MVA P/TF T-3                         | 17.09.24 | Tuesday   | 8:30 | 14:30 | Annual maintenance / testing        | 11KV O/G Jahan Khan & Jaffar Shah feeders (02-Feeders)  | Muhammad Akram Foreman Cell # 0319-9765770 |
| 15      | MEPCO | 132KV Ludden/ 132/11KV 20/26MVA P/TF T-1                           | 17.09.24 | Tuesday   | 8:00 | 14:00 | Annual Maintenance/testing          | 11 KV O/G Ludden, Firdous, Sajwar Shahed, Farooq Shahed feeders   | Abdul Rahman (AEM Vehari) 0319-9765644     |
| 16      | MEPCO | 132KV Qabula / 132/11KV 20/26MVA P/TF T-2                          | 18.09.24 | Wednesday | 8:30 | 14:30 | Annual maintenance / testing        | 11KV O/G Aslam Shahed, Mehdi Khan, Ahmad Yar, (03-Feeders)  | Muhammad Akram Foreman Cell # 0319-9765770 |
| 17      | MEPCO | 132KV Fort Abbas/ 132/11KV 20/26MVA P/TF T-1                       | 18.09.24 | Wednesday | 9:00 | 15:00 | Annual Maintenance/testing          | 11 KV O/G City, Quraish, Rafiq Shahed, THQ Hospital feeders   | Abdul Rahman (AEM Vehari) 0319-9765644     |
| 18      | MEPCO | 132KV Garha More-Jehanian T/L controlled by 132KV CB GRM-2 - JHN-4 | 18.09.24 | Wednesday | 6:30 | 10:30 | Washing/cleaning of disc Insulators | No area will be affected due to dual source. Only 20-25 MW load shed will be required from 132KV G/S Garha More, Jehanian, Chak 211W/B and Mallisi  | Obaid Ullah (AET Vehari) 0319-9765641      |
| 19      | MEPCO | 132KV Khanewal/ 132/11KV 31.5/40MVA P/TF T-2                       | 19.09.24 | Thursday  | 9:00 | 15:00 | Annual maintenance/ testing.        | 11KV O/G Kot Mala Ram, Ibrahim City, Jahangir Abad, Zahoor Abad, City-5, Kot Madina, Maryala, Jadeed Feeds, Aziz Jadeed, P.G.H.S. (10-No Feeders)   | Muhammad Akram Foreman Cell # 0319-9765770 |
| 20      | MEPCO | 132KV Fort Abbas/ 132/11KV 20/26MVA P/TF T-2                       | 19.09.24 | Thursday  | 6:30 | 12:30 | Annual Maintenance/testing          | 11 KV O/G Khichi Wala, Walhar, Fort, Rafique Abad feeders   | Abdul Rahman (AEM Vehari) 0319-9765644     |
| 21      | MEPCO | 132KV Kehror Pacca-Dunya Pur T/L controlled by 132KV CB KRP-1 -101 | 19.09.24 | Thursday  | 7:30 | 11:30 | Washing/cleaning of disc Insulators | Whole area of 132KV G/S Dunya Pur (11 KV O/G Ali Sher, Thatha Road, Sada, Khushi Muhammad, City Noor Peer, Ghulam Rasool, Jallah, City Dunya Pur, Qutab Pur, Nasrullah Tarn, Model Town & Sadiq Shahed feeders) | Obaid Ullah (AET Vehari) 0319-9765641      |
| 22      | MEPCO | 132KV Sahiwal New/ 132/11KV 31.5/40MVA P/TF T-1                    | 23.09.24 | Monday    | 8:00 | 14:00 | Annual maintenance / testing        | 11KV O/G Civil Hospital, T.V Corporation, College Road, Kouray Shah, Noor Shah, Asiyana Housing Scheme, DHQ Teaching Hospital, Ratti Tibbi. (08-Feeders)  | Muhammad Akram Foreman Cell # 0319-9765770 |
| 23      | MEPCO | 132KV Chak 211W/B/ 132/11KV 20/26MVA P/TF T-1                      | 23.09.24 | Monday    | 8:00 | 14:00 | Annual Maintenance/testing          | 11 KV O/G Rashid Mirhas Shahed, Noor Garh, Sher Muhammad Ghali feeders  | Abdul Rahman (AEM Vehari) 0319-9765644     |
| 24      | MEPCO | 132KV Qabula / 132/11KV 20/26MVA P/TF T-1                          | 24.09.24 | Tuesday   | 8:30 | 14:30 | Annual maintenance/ testing         | 11KV O/G Mouj Darya, Muhammad Nagar, Peer Fazal, Shehar Jilani. (04-Feeders)  | Muhammad Akram Foreman Cell # 0319-9765770 |

Peer Fazal

| Sr. No. | Disco | Name of Grid Station / Name of Equipment                                  | Date     | Day       | Time |       | Purpose of Shut Down                     | Affected Area   | Safety Supervisor                                 |
|---------|-------|---|----------|-----------|------|-------|--|---|---|
|         |       |   |          |           | From | To    |  |   |   |
| 25      | MEPCO | 132KV T/L Burewala Old - Sahuka controlled by<br>132KV CB BWO-2 -SKA-1    | 24.09.24 | Tuesday   | 8:00 | 13:00 | Washing / cleaning of disc<br>insulators | 11KV O/G Sadat, Umar Pur, Al-Abas,<br>Murad Ali, Jamliya, Sahuka, Saldara,<br>Sarwar Shah, Haji Sher, Jodhaka,<br>Subhan Shah & Yousef Shahneed (12-<br>No feeders)   | Altar Hussain, LS-1<br>Cell # 0319-9765744        |
| 26      | MEPCO | 132KV Chishtian/ 132/11KV 20/26 MVA PTF T-1                               | 24.09.24 | Tuesday   | 8:00 | 14:00 | Annual Maintenance/testing               | 11 KV O/G City-2nd College,<br>Marghair Sharif, Eid Gah Road<br>and Muner Shahneed feeders  | Abdul Rahman (AEM<br>Vehari) 0319-9765644         |
| 27      | MEPCO | 132KV Sahwal-III / 132/11KV 20/26MVA PTF T-2                              | 25.09.24 | Wednesday | 8:00 | 14:00 | Annual maintenance / testing             | 11KV O/G Jehaz Ground, Police Line,<br>Abdullahi Shah, Central Jail, Rafi<br>Garden, Booti Pall, Qutab Shahana<br>(07-Feeders)  | Muhammad Akram<br>Foreman<br>Cell # 0319-9765770  |
| 28      | MEPCO | 132KV Faqir Wail/ 132 KV Bus Bar controlled by<br>132KV CB FQW-1 - FQW-2  | 25.09.24 | Wednesday | 8:30 | 14:30 | Annual Maintenance 132KV bus<br>bar      | Whole area of 132KV G/S Faqir<br>Wail, Khichi Wala, Fort Abbas and<br>Marrot.<br>(11 KV O/G City Faqir Wail, Wains,<br>Canal 7R, City-II Faqir Wail, Yateem<br>Wala, Rural, Mehria City, Sidhu, City<br>Fort Abbas, Fort, Quraish, Rafiq<br>Shahneed, Khichi Wala, Walhar,<br>Rafique Abad, THQ Hospital Fort<br>Abbas, Gafoor Shahneed, City Khichi<br>Wala, 75 Adda, Fazal Shah, Latif<br>Abad, Marrot-I, City Marrot,<br>Mansoor, Cholistan, Zia, Rohi,<br>Sardar, Chappu & Meer Garh feeders) | Abdul Rahman (AEM<br>Vehari)<br>0319-9765644      |
| 29      | MEPCO | 132KV Vehari 220 KV/Garha More T/L controlled by<br>132KV CB E1Q1 - GRM-1 | 25.09.24 | Wednesday | 7:30 | 11:30 | Washing/cleaning of disc<br>insulators   | No area will be affected due to dual<br>source. Only 20-25 MW load shed will<br>be required from 132KV G/S Garha<br>More, Jehanian, Chak 211/W/B and<br>Malsi   | Obaid Ullah (AET Vehari)<br>0319-9765641          |
| 30      | MEPCO | 132KV Haroon Abad-Faqir Wail T/L controlled by<br>132KV CB HRB-3 - FQW-1  | 25.09.24 | Wednesday | 8:30 | 14:30 | Washing/cleaning of disc<br>insulators   | Whole area of 132KV G/S Faqir<br>Wail, Khichi Wala, Fort Abbas and<br>Marrot.<br>(11 KV O/G City Faqir Wail, Wains,<br>Canal 7R, City-II Faqir Wail, Yateem<br>Wala, Rural, Mehria City, City Fort<br>Abbas, Fort, Quraish, Rafiq Shahneed,<br>Khichi Wala, Walhar, Rafique Abad,<br>THQ Hospital Fort Abbas, Gafoor<br>Shahneed, City Khichi Wala, 75 Adda,<br>Fazal Shah, Latif Abad, Marrot-I, City<br>Marrot, Mansoor, Cholistan, Zia,<br>Rohi, Sardar, Chappu & Meer Garh<br>feeders)        | Behzad Ali (AET Bahawal<br>Nagar)<br>0319-9765643 |
| 31      | MEPCO | 132KV Arifwala / 132/11KV 31.5/40MVA PTF T-1                              | 26.09.24 | Thursday  | 8:00 | 14:00 | Annual maintenance / testing             | 11KV O/G Old Factory, Qalander<br>Shah, City Magger, Kaiyana, Al-<br>Madni, (06-Feeders)  | Muhammad Akram<br>Foreman<br>Cell # 0319-9765770  |
| 32      | MEPCO | 132KV Chuna Wala/ 132 KV Bus Bar controlled by<br>132KV CB CNW-1          | 26.09.24 | Thursday  | 8:00 | 11:00 | Annual Maintenance 132KV bus<br>bar      | Whole area of 132KV G/S Chuna<br>Wala (Whole area of 11KV O/G City<br>Chuna Wala, New Cholistan and Al-<br>Fateh feeders)   | Abdul Rahman (AEM<br>Vehari) 0319-9765644         |
| 33      | MEPCO | 132KV Vehari 220KV-Burewala T/L controlled by<br>132KV CB E11Q1 - BRW-5   | 26.09.24 | Thursday  | 6:30 | 10:30 | Washing/cleaning of disc<br>insulators   | No area will be affected due to dual<br>source. Only 30-40 MW load shed will<br>be required from 132KV G/S<br>Burewala, Burewala Old and Sahuka   | Obaid Ullah (AET Vehari)<br>0319-9765641          |

P=03

| Sr: No. | Disco | Name of Grid Station / Name of Equipment                               | Date     | Day      | Time |       | Purpose of Shut Down                     | Effectuated Area  | Safety Supervisor                            |
|---------|-------|--|----------|----------|------|-------|--|---|--|
|         |       |  |          |          | From | To    |  |   |  |
| 34      | MEPCO | 132KV Hasil Pur-Chuna Wala T/L controlled by<br>132KV CB HSP-7 - CNW-1 | 26.09.24 | Thursday | 8:00 | 11:00 | Washing/cleaning of disc<br>insulators   | Whole area of 132KV G/S Chuna Wala (Whole area of 11KV O/G City Chuna Wala, New Cholistan and Al-Fateh feeders)   | Fazal Ur Rehman (AET Hasil Pur) 0319-9765642 |
| 35      | MEPCO | 132KV Vehari-Burewala T/L controlled by<br>132KV CB VRI-1 - BRW-4      | 27.09.24 | Friday   | 6:30 | 10:30 | Washing/cleaning of disc<br>insulators   | No area will be affected due to dual source. Only 30-40 MW load shed will be required from 132KV G/S Burewala, Burewala Old and Sahuka                                    | Obaid Ullah (AET Vehari) 0319-9765641        |
| 36      | MEPCO | 132KV Sahukal 132/11KV 31.5/40MVA P/TF T-2                             | 30.09.24 | Monday   | 9:00 | 15:00 | Annual maintenance / testing             | 11KV O/G Jamliya, Sahuka, Saidara, Sarwar Shah, Haji Sher, Jodhaka, Subhan Shah & Yousof Shaheed (08-feeders)   | Muhammad Akram Foreman Cell # 0319-9765770   |
| 37      | SWL   | 132KV Noor Pur -Pakpattan T/L controlled by<br>132KV CB NPR-3-PPT-1    | 30.09.24 | Monday   | 7:00 | 12:00 | Washing / cleaning of disc<br>insulators | 11KV O/G DHQ Hospital, Noor Shah, Ratta Tibba, New Chak 37W/B, Machawal, Dana Ibraheem, SS Oil Mills, District Jail Vehari, Bilal, Industrial Estate & Pakh More feeders  | M. Nafees, LS-I Cell # 0319-9765678          |
| 38      | MEPCO | 132KV Vehari/ 132/11KV 31.5/40 MVA P/TF T-1                            | 30.09.24 | Monday   | 7:30 | 14:30 | Annual Maintenance/testing               | 11 KV O/G DHQ Hospital, Noor Shah, Ratta Tibba, New Chak 37W/B, Machawal, Dana Ibraheem, SS Oil Mills, District Jail Vehari, Bilal, Industrial Estate & Pakh More feeders | Abdul Rahman (AEM Vehari) 0319-9765644       |
| 39      | MEPCO | 132KV Vehari 220KV-Jehanian T/L controlled by<br>132KV CB E3Q1 - JHN-2 | 30.09.24 | Monday   | 6:30 | 10:30 | Washing/cleaning of disc<br>insulators   | No area will be affected due to dual source. Only 40-50 MW load shed will be required from 132KV G/S Garha More, Jehanian, Chak 211W/B and Malisi                         | Obaid Ullah (AET Vehari) 0319-9765641        |
| 40      | MEPCO | 132KV Ludden-Karam Pur T/L controlled by<br>132KV CBS LDN-2 - KPU-1    | 30.09.24 | Monday   | 7:30 | 12:30 | Washing/cleaning of disc<br>insulators   | Whole area of 132KV G/S Karam Pur (11KV Atab Mehmood, Tipu, Muhammad Shah, Hassan Shah, Zia Shahheed, Karam Pur, Tabark Wah & Idrees Shahheed feeders)                    | Fazal Ur Rehman (AET Hasil Pur) 0319-9765642 |

*P=24*