

SHUT DOWNS ON 132KV TRANSMISSION LINES / GRID STATIONS

I.R.O GSO CIRCLE MEPCO SAHIWAL FOR 05/2024

Sr. No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effectuated Area	Safety Supervisor
					From	To			
1	MEPCO	132KV Pakpattan/ 132KV Bus Bar controlling 132KV CB PPT-1	23.05.24	Thursday	8.00	10.00	To replace heated clamp of Bus Bar Isolator 81-1	11KV O/G Power House, Chak Shafi, Sanday Kha, Malka Hance, Khawaja Aziz Makki, Husain Abad, Chan Peer, Al-Fareed, New Malka Hance, Bonga Hayat, Fareed Nager, Ghulam Hayder, Sarwar Shaheed, Mehboob Shah, Jail, D.H.Q, Mubasher Shaheed, Dost Muhammad, Moj Darya, Masoom Shah, City, Satluj, Miran Shah, Gunj Shakar, Iqbal Shaheed, Abdul Kareem, Mushtaq Shaheed, Ali Mahi. <u>(28-No feeders)</u>	Muhammad Akram FM Cell # 0302-7892530 0319-9765770
2	MEPCO	132KV Harappa/ 132/11KV, 3.15/40 MVA P/TF T-1	27.05.27	Monday	19.30	23.30	To connect 03-No 1000MCM Power Cables with each Phase to enhance the loading capacity	11KV O/G City, Jinnah Town, Nai Wala, Khaki Shah, Tareen Cold Storage, Ahsan Abad, Shoaib Suleman Mills U-2, Eden Milk U-2, Ravi, Adam's Cold Storage, Kool Wala, Mian Textike Mills Harappa, <u>(12-No Feeders)</u>	Muhammad Akram FM Cell # 0302-7892530 0319-9765770

P-01/12

/83
111
1.1528
197.6