

**SHUT DOWNS ON 132KV TRANSMISSION LINES / GRID STATIONS**

**I.R.O GSO CIRCLE MEPCO SAHIWAL FOR 12/2024 (Area Affect)**

Sr. No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
1	MEPCO	132KV Pakpattan/ 132/11KV 20/26MVA P/TF T-4	03.12.24	Tuesday	9.00	15.00	Annual maintenance / testing	11KV O/G Iqbal Shaheed, Abdul Kareem, Mushtaq Shaheed, Ali Mahi. <u>(04-No feeders)</u>	Muhammad Akram FM Cell # 0319-9765770
2	MEPCO	132KV Makhdoom Pur Pohoran/ 132/11KV 20/26MVA P/TF T-1	04.12.24	Wednesday	9.00	15.00	Annual maintenance / testing	11KV O/G Jodh Pur, Makhdoom Pur City, Noor Pur, Chak 13/8-R, Hiraj Cotton, <u>(05-No Feeders)</u>	Muhammad Akram FM Cell # 0319-9765770
3	MEPCO	132KV Marrot/ 132/11KV 20/26MVA P/TF T-1	04.12.24	Wednesday	9:30	15:30	Annual Maintenance/testing	11 KV O/G Zia, Cholistan, Rohi, Meer Garh feeders	Abdul Rahman (AEM Vehari) 0319-9765644
4	MEPCO	132KV Noor Pur/ 132/11KV 20/26MVA P/TF T-2	05.12.24	Thursday	9.00	15.00	Annual maintenance / testing	11KV O/G Sher Shah, Noor Pur, Hari Pur, Chak Ghuri, Fouji Fresh & Freez, <u>(05-No Feeders)</u>	Muhammad Akram FM Cell # 0319-9765770
5	MEPCO	132KV Fort Abbas-Marrot T/L controlled by 132KV CB FTA-2 - MRT-2	05.12.24	Thursday	7:30	10:30	Washing/cleaning of disc insulators	<b>Whole area of 132KV G/S Marrot</b> (11 KV O/G Marrot-I, City Marrot, Mansoor, Cholistan, Zia, Rohi, Sardar, Chappu & Meer Garh feeders)	Behzad Ali (AET Bahawal Nagar) 0302-8290668
6	MEPCO	132KV Marrot/ 132KV Bus Bar controlled by 132KV CB MRT-2	05.12.24	Thursday	7:30	10:30	Annual maintenance of 132KV bus bar & 132KV CB MRT-2	<b>Whole area of 132KV G/S Marrot</b> (11 KV O/G Marrot-I, City Marrot, Mansoor, Cholistan, Zia, Rohi, Sardar, Chappu & Meer Garh feeders)	Abdul Rahman (AEM Vehari) 0319-9765644
7	MEPCO	132KV Marrot/ 132/11KV 20/26MVA P/TF T-2	05.12.24	Thursday	8:00	14:00	Annual Maintenance/testing	11 KV O/G Marrot 1st, Mansoor, Sardar, Chapu feeders	Abdul Rahman (AEM Vehari) 0319-9765644
8	MEPCO	132KV Vehari 220KV-Garha More T/L controlled by 132KV CB E1Q1 - GRM-1	05.12.24	Thursday	9:00	15:00	Washing/cleaning of disc insulators	No area will be affected due to dual source. Only 20-25 MW load shed will be required from 132KV G/S Garha More, Jehanian, Chak 211/W.B and Mailsi	Obaid Ullah (AET Vehari) 0319-9765641
9	MEPCO	132KV Vehari-Burewala T/L controlled by 132KV CB VRI-1- BRW-4	06.12.24	Friday	8:30	12:30	Washing/cleaning of disc insulators	No area will be affected due to dual source. Only 20-30 MW load shed will be required from 132KV G/S Burewala, Burewala Old and Sahuka	
10	MEPCO	132KV Mianchannu/ 132/11KV 31.5/40MVA P/TF T-1	09.12.24	Monday	9.00	15.00	Annual maintenance / testing	11KV O/G Tulamba, Dilon Banglow, Mumdoot, Bura Road, Chak 95, Chak 98, <u>(06-No feeders)</u>	Muhammad Akram FM Cell # 0319-9765770
11	MEPCO	132KV Kehror Pacca-Dunya Pur T/L controlled by 132KV CB KRP-1 - 101	09.12.24	Monday	9:00	15:00	Washing/cleaning of disc insulators	<b>Whole area of 132KV G/S Dunya Pur</b> (11 KV O/G Ali Sher, Thatha Road, Sadat, Khushi Muhammad, City Noor Peer, Ghulam Rasool, Jallah, City Dunya Pur, Qutab Pur, Nasrullah Tarin, Model Town & Sadiq Shaheed feeders)	Obaid Ullah (AET Vehari) 0319-9765641

P=01

Sr. No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
12	MEPCO	132KV Burewala 132/11KV 31.5/40MVA P/TF T-2	10.12.24	Tuesday	9.00	16.00	Annual maintenance / testing	11KV O/G Lahore Road, BTM-3, Tufail Shaheed, City-1, Shah Faisal, Royal Garden, Dallon Banglow, Kamand, <b>(08-No Feeders)</b>	Muhammad Akram FM Cell # 0319-9765770
13	MEPCO	132KV Chishtian/ 132/11KV 20/26 MVA P/TF T-1	10.12.24	Tuesday	9:00	14:00	Replacement of Incoming panel of P/TF T-2	11 KV O/G City-2nd, College, Manghair Sharif, Eid Gah Road and Muneer Shaheed feeders	Abdul Rahman (AEM Vehari) 0319-9765644
14	MEPCO	132KV Chishtian/ 132/11KV 20/26 MVA P/TF T-2	10.12.24	Tuesday	9:00	17:00	Annual maintenance and to replace the 04 No. 11KV O/G panels	11 KV O/G City-1st, Azeem Wah, THQ Hospital, 3 Marla Housing Scheme, Sattuj, Fareed Kot feeders	Abdul Rahman (AEM Vehari) 0319-9765644
15	MEPCO	132KV Vehari 220KV-Burewala T/L controlled by 132KV CB E11Q1 - BRW-5	10.12.24	Tuesday	9:00	15:00	Washing/cleaning of disc insulators	No area will be affected due to dual source. Only 20-30 MW load shed will be required from 132KV G/S Burewala, Burewala Old and Sahuka	Obaid Ullah (AET Vehari) 0319-9765641
16	MEPCO	132KV Bahawal Nagar II Minchin Abad T/L controlled by 132KV CB BNR-2 - MNA-1	10.12.24	Tuesday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Minchin Abad & Mecleod Gunj (11 KV O/G Fidai Shah, City Minchin Abad, Railway Road, Farooq Shaheed, Mehmood, PPN Road M/Gunj, M.S.G Road, M.Abad-II, Anwar Shaheed, Al-Mushtaq, City, Amruka, M/Abad/1 & Head Sulemanki feeders)	Behzad Ali (AET Bahawal Nagar) 0319-9765643
17	MEPCO	132KV Harappa/ 132/11KV 20/26MVA P/TF T-2	11.12.24	Wednesday	8.30	15.30	Annual maintenance / testing	11KV O/G Sahiwal Road, Harappa Textile Mill, Shah Murad, S.S.T Mill, Ganji Bar, Suraj Fertilizer, Sadiq Feed Mills <b>(07 No Feeders)</b>	Muhammad Akram FM Cell # 0319-9765770
18	MEPCO	132KV Bahawal Nagar/132/11KV 20/26MVA P/TF T-3	11.12.24	Wednesday	9:30	15:30	Annual Maintenance/testing	11 KV O/G New City Housing Scheme, District Jail Bahawal Nagar, Canal, Ada Khiraj Pura, Nawab Sadiq, Ibraheem Shaheed, Star City, Ahmad Hassan Rice Mill feeders	Abdul Rahman (AEM Vehari) 0319-9765644
19	MEPCO	132KV Hasil Pur-Chuna Wala T/L controlled by 132KV CB HSP-7 - CNW-1	11.12.24	Wednesday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Chuna Wala (Whole area of 11KV O/G City Chuna Wala, New Cholistan and Al-Fateh feeders)	Fazal Ur Reham (AET Hasil Pur) 0319-9765642
20	MEPCO	132KV Haroon Abad-Faqir Wali T/L controlled by 132KV CB HRB-3 - FQW-1	11.12.24	Wednesday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Faqir Wali, Khichi Wala, Fort Abbas and Marrot. (11 KV O/G City Faqir Wali, Wains, Canal 7R, City-II Faqir Wali, Yateem Wala, Rural, Mehria City, Sidhu, City Fort Abbas, Fort, Quraish, Rafiq Shaheed, Khichi Wala, Walhar, Rafique Abad, THQ Hospital Fort Abbas, Gafar Shaheed, City Khichi Wala, 75 Adda, Fazal Shah, Latif Abad, Marrot-I, City Marrot, Mansoor, Cholistan, Zia, Rohi, Sardar, Chappu & Meer Garh feeders)	Behzad Ali (AET Bahawal Nagar) 0319-9765643
21	MEPCO	132KV Burewala / 132/11KV 31.5/40MVA P/TF T-3	12.12.24	Thursday	9.00	16.00	Annual maintenance / testing	11KV O/G City-3, Masoom Shah, City-4, Mujahid Colony, Gaggo. Zaheer Nager, Ghallah Mandi, Sabar Raza Shaheed <b>(08-No Feeders)</b>	Muhammad Akram FM Cell # 0319-9765770
22	MEPCO	132KV Mecleod Gunj/ 132/11KV 20/26MVA P/TF T-2	12.12.24	Thursday	7:30	13:30	Annual Maintenance/testing	11KV O/G City, Amruka, M/Abad-1, Head Sulemanki feeders	Abdul Rahman (AEM Vehari) 0319-9765644

P-02/12



Sr. No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effectuated Area	Safety Supervisor
					From	To			
23	MEPCO	132KV Haroon Abad-Donga Bonga T/L controlled by 132KV CBs HRB-5 -DBA-1	12.12.24	Thursday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Donga Bonga (11KV City Donga Bonga, Rasool Pura, Muhib Ali, Chishti feeders)	Behzad Ali (AET Bahawal Nagar) 0319-9765643
24	MEPCO	132KV Mianchannu /132/11KV 31.5/40MVA P/TF T-3	16.12.24	Monday	9.00	16.00	Annual maintenance / testing	11KV O/G J.T.M, Q.T.M, M.T.M, New Kassowal, City-4, L.B.H.S. S.P.Mills, Bodhla, A.U.P.M, City-2, Industrial Estate, City-3, Chak 8-BR, Chak 13 (14-No feeders)	Muhammad Akram FM Cell # 0319-9765770
25	MEPCO	132KV Kehror Pacca/ 132KV Bus Bar controlled by 132KV CB KRP-1, KRP-2, KRP-3, KRP-4	16.12.24	Monday	9:00	15:00	Annual Maintenance of 132KV bus bar	Whole area of 132KV G/S Kehror Pacca and Dunya Pur (11 KV O/G City-II, Bukhari Wahin, Noaqabil Wah, Burhan pur, Satluj, Tibba Sadat, Sarfraz Shaheed, Factory, Goth Bahar, City Kehror Pacca, Fateh Shah, Main Bazar, Mustafa Shaheed, Shah Muhammad, Shah Pur, Sohail Pur, Ali Pur, Mehar Shah, Anayat ALI, Mangwani, Qadir Pur Cheema, Ali Sher, Thatha Road, Sadat, Khushi Muhammad, City Noor Peer, Ghulam Rasool, Jallah, City Dunya Pur, Qutab Pur, Nasrullah Tarin, Model Town & Sadiq Shaheed feeders)	Abdul Rahman (AEM Vehari) 0319-9765644
26	MEPCO	132KV Ludden-Karam Pur T/L controlled by 132KV CBs LDN-2 - KPU-1	16.12.24	Monday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Karam Pur (11KV Aftab Mehmood, Tipu, Muhammad Shah, Hassan Shah, Zia Shaheed, Karam Pur, Tabark Wah & Idrees Shaheed feeders)	Fazal Ur Reham (AET Hasil Pur) 0319-9765642
27	MEPCO	132KV Pakpattan/ 132/11KV 31.5/40MVA P/TF T-2	17.12.24	Tuesday	9.00	16.00	Annual maintenance / testing	11KV O/G Al-Fareed, New Malka Hance, Bonga Hayat, Fareed Nager, Ghulam Hayder, Sarwar Shaheed, Mehboob Shah, Jail, D.H.Q. Mubasher Shaheed, Dost Muhammad, Moj Darya, (12-No feeders)	Muhammad Akram FM Cell # 0319-9765770
28	MEPCO	132KV Haroon Abad/ 132/11KV 20/26MVA P/TF T-2	17.12.24	Tuesday	9:30	15:30	Annual Maintenance/testing	11 KV O/G Muslim City, City-2, Mian Wala Banglow, THQ Hospital, Grain Market feeders	Abdul Rahman (AEM Vehari) 0319-9765644
29	MEPCO	132KV Head Sidhnai/132/11KV 20/26MVA P/TF T-2	18.12.24	Wednesday	9.30	15.30	Annual maintenance / testing	11KV O/G Qatal Pur, Tulamda, Tulamba City-2 & Sidhnai Feeders (04-No feeders)	Muhammad Akram FM Cell # 0319-9765770
30	MEPCO	132KV Haroon Abad/ 132/11KV 20/26MVA P/TF T-3	18.12.24	Wednesday	7:30	13:30	Annual Maintenance/testing	11 KV O/G Model Avenue, Pul Murad, Donga Bonga, Khatan, Eastern Products VITAL Pvt Ltd. feeders	Abdul Rahman (AEM Vehari) 0319-9765644
31	MEPCO	132KV Garha More-Jehanian T/L controlled by 132KV CB GRM-2 - JHN-4	18.12.24	Wednesday	9:00	15:00	Washing/cleaning of disc insulators	No area will be affected due to dual source. Only 20-25 MW load shed will be required from 132KV G/S Garha More, Jehanian, Chak 211/W.B and Mailis	Obaid Ullah (AET Vehari) 0319-9765641
32	MEPCO	132KV Faqir Wali-Khichi Wala T/L controlled by 132KV CB FQW-2 - KHW-1	18.12.24	Wednesday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Khichi Wala, Fort Abbas and Marrot. (11 KV O/G City Fort Abbas, Fort, Quraish, Rafiq Shaheed, Khichi Wala, Walhar, Rafique Abad, THQ Hospital Fort Abbas, Gafoor Shaheed, City Khichi Wala, 75 Adda, Fazal Shah, Latif Abad, Marrot-I, City Marrot, Mansoor, Cholistan, Zia, Rohi, Sardar, Chappu & Meer Garh feeders)	Behzad Ali (AET Bahawal Nagar) 0319-9765643

P-03/2

Sr: No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
33	MEPCO	132KV Makhdoom Pur Pahoran/ 132/11KV 20/26MVA P/TF T-2	19.12.24	Thursday	9.00	15.00	Annual maintenance / testing	11KV O/G Pirowal-II, Chak 3/AH Choperhata (03-No Feeders)	Muhammad Akram FM Cell # 0319-9765770
34	MEPCO	132KV Vehari/ 132KV bus bar controlled by 132KV CBs VRI-1, VRI-2, VRI-3, VRI-4 & VRI-5	19.12.24	Thursday	9:00	15:00	Annual Maintenance of 132KV bus bar	Whole area of 132KV G/S Vehari (11KV DHQ Hospital, Noor Shah, Ratta Tibba, New Chak 37/W.B, Machiwal, Dana Ibraheem, SS Oil Mills, Disst. Jail Vehari, Balal, Industrial Estate, Pakhi More, Water Works, City-I, MES Thingi, Liaqat Shaheed, TRW Vehari, City-II, T/Shahed, Chak 37/W.B, Club Road, Chak 22/W.B, C/Factory, Chak 182/EB, Defence View, SS Feed, City-III, Madina Colony, Defence View VIP Block feeders)	Abdul Rahman (AEM Vehari) 0319-9765644
35	MEPCO	132KV Chishtian 220KV-Dahran Wala T/L controlled by 132KV CB E8Q1 - DNW-1	19.12.24	Thursday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Dahran Wala (11 KV O/G City Chuna Wala, Bukhshan Khan, Al Gazi, Al Fateh, AL Murad, Shaheed Chowk and City Dahran Wala feeders)	Fazal Ur Reham (AET Hasil Pur) 0319-9765642
36	MEPCO	132KV Chak 83/12-L/ 132/11KV 20/26MVA P/TF T-2	23.11.24	Monday	9.00	15.00	Annual maintenance / testing	11KV O/G Al-Rehman, S.S.Din, Baba Fareed & Jaman Shah. (04-No Feeders)	Muhammad Akram FM Cell # 0319-9765770
37	MEPCO	132KV Noor Pur -Pakpattan T/L controlled by 132KV CB NPR-3-PPT-1	23.11.24	Monday	9.00	14.00	Washing / cleaning of disc insulators	11KV O/G Power House, Chak Shafi, Sanday Kha, Malka Hance, Khawaja Aziz Makki, Husain Abad, Chan Peer, Al-Fareed, New Malka Hance, Bonga Hayat, Fareed Nager, Ghulam Hayder, Sarwar Shaheed, Mehmoob Shah, Jail, D.H.Q, Mubasher Shaheed, Dost Muhammad, Moj Darya, Masoom Shah, City, Satuj, Miran Shah, Gunj Shakar, Iqbal Shaheed, Abdul Kareem, Mushtaq Shaheed, Ali Mahi. (28-No feeders)	M. Nafees, LS-I Cell # 0319-9765678
38	MEPCO	132KV Mailsi/132/11KV 31.5/40MVA P/TF T-2	23.12.24	Monday	9:00	15:00	Annual Maintenance/testing	11 KV O/G City-1, Shakar Ganj, Sardar Jhandir, Jallah, Kikri Khurd, RCA Colony, Khan Pur, Ameer Shaheed. feeders	Abdul Rahman (AEM Vehari) 0319-9765644
39	MEPCO	132KV Sahuka/ 132KV Bus Bar controlled by 132KV CB SKA-1	24.12.24	Tuesday	9.00	15.00	Annual maintenance of 132KV Bus Bar and line isolator No. 101 along with 11KV Bus Coupler & Tightening of 11KV cables	11KV O/G Sadat, Umar Pur, Al-Abas, Murad Ali, Jamlarya, Sahuka, Saldara, Sarwar Shah, Haji Sher, Jodhaka, Subhan Shah & Yousaf Shaheed Feeders (12-No feeders)	Muhammad Akram FM Cell # 0319-9765770
40	MEPCO	132KV Shuka / 132KV Sahuka-Burewala old T/L controlled by 132KV CB SKA-1-BWO-2	24.12.24	Tuesday	9.00	12.00	Annual maintenance / testing of 132KV CB SKA-1 & Line Isolator No. 101		Muhammad Akram FM Cell # 0319-9765770
41	MEPCO	132KV Ludden/132/11KV 20/26MVA P/TF T-2	24.12.24	Tuesday	9:00	15:00	Annual Maintenance/testing	11 KV O/G Ahmad Abad, Dolat Abad, Nadir Wali, Shams Abad, Head Islam feeders	Abdul Rahman (AEM Vehari) 0319-9765644
42	MEPCO	66KV Hasil Pur-Chishtian T/L controlled by 66KV CB HSP-5 - CHN-1	24.12.24	Tuesday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 66KV Grid Station Bukhshan Khan and Chishtian (11 KV O/G Madrassa, Main Bazar, Park, Gulshan, City-I Bukhshan Khan, Syadan Wala & City-II Bukhshan Khan feeders)	Fazal Ur Reham (AET Hasil Pur) 0319-9765642



Sr: No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effectuated Area	Safety Supervisor
					From	To			
43	MEPCO	132KV Arifwala/ 132KV Bus Bar controlled by 132KV CBs ARW-1, 2, 3, 4, 6 & 7	26.12.24	Thursday	9:00	16:00	Annual maintenance of 132KV Bus Bar and line isolator No. 101, 102, 103, 104, 106 & 107, 11KV Bus Coupler, and tightening of all power cables	11KV O/G Old Factory, Qalander Shah, City, Magger, Kalyana, Al-Madni, Power House, Chak 67, Nawaban Wala, Jeween Shah, Burewala Road, Arif Shaheed, Gunj Shakar, Jinah, Qabula, New Factory, Hoota, Karmanwala, Muhammad Pannah, T.H.Q, Gulshan Iqbal, Syed Irshad Shah, Rang Shah, Ghulam Qadar, Trakhni, Pir Bushkh & Sufi Zaman Shaheed. <b>(27-No Feeders)</b>	Muhammad Akram FM Cell # 0319-9765770
44	MEPCO	132KV Hasil Pur/ 132/11KV 20/26MVA P/TF T-2	26.12.24	Thursday	9:00	15:00	Annual Maintenance/testing	11 KV O/G Hospital, Jmal Pur, Vehari Road, Old Hasil Pur, Satluj feeders	Abdul Rahman (AEM Vehari) 0319-9765644
45	MEPCO	132KV Kehror Pacca-Dunya Pur T/L controlled by 132KV CB KRP-1 & 101	26.12.24	Thursday	9:00	15:00	Washing/cleaning of disc insulators	<b>Whole area of 132KV G/S Dunya Pur (11 KV O/G Ali Sher, Thatha Road, Sadat, Khushi Muhammad, City Noor Peer, Ghulam Rasool, Jallah, City Dunya Pur, Qutab Pur, Nasrullah Tarin, Model Town &amp; Sadiq Shaheed feeders)</b>	Obaid Ullah (AET Vehari) 0319-9765641
46	MEPCO	132KV Hasil Pur-Chuna Wala T/L controlled by 132KV CB HSP-7 - CNW-1	26.12.24	Thursday	9:00	15:00	Washing/cleaning of disc insulators	<b>Whole area of 132KV G/S Chuna Wala (Whole area of 11KV O/G City Chuna Wala, New Cholistan and Al-Fateh feedes)</b>	Fazal Ur Reham (AET Hasil Pur) 0319-9765642
47	MEPCO	132KV Khichi Wala-Fort Abbas T/L controlled by 132KV CB KHW-2 - FTA-1	26.12.24	Thursday	9:00	15:00	Washing/cleaning of disc insulators	<b>Whole area of 132KV G/S Fort Abbas and Marrot. (11 KV O/G City Fort Abbas, Fort, Quraish, Rafiq Shaheed, Khichi Wala, Walhar, Rafique Abad, THQ Hospital Fort Abbas, Marrot-I, City Marrot, Mansoor, Cholistan, Zia, Rohi, Sardar, Chappu &amp; Meer Garh feeders)</b>	Behzad Ali (AET Bahawal Nagar) 0319-9765643
48	MEPCO	132KV Chichawatni/ 132/11KV 20/26MVA P/TF T-3	30.12.24	Monday	9:00	15:00	Annual maintenance / testing	11KV O/G Sheikh Tayyab, New City, Industrial <b>(03-No Feeders)</b>	Muhammad Akram FM Cell # 0319-9765770

*Handwritten signature/initials*

*P=05*