

TECHNICAL EVALUATION REPORT
(As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency: MULTAN ELECTRIC POWER COMPANY LTD, MULTAN
2. Method of Procurement: Single Stage Two Envelop
3. Title of Procurement: Procurement of 132KV Capacitors & Control Equipment.
4. Tender Inquiry No.: Tender No. 07/2023-24
5. PPRA Ref. No. (TSE): TS516330E.
6. Date & Time of Bid Closing: 20.09.2023 at 12:00
7. Date & Time of Bid Opening: 20.09.2023 at 12:30
8. No of Bids Received: One (01)
9. Criteria for Bid Evaluation: As per bidding document
10. Details of Bid(s) Evaluation: As under:-

Name of Bidder	Technical Marks (if applicable)	Rule/Regulation/SBD*/Policy/ Basis for Technical Rejection / Acceptance as per Rule 35 of PP Rules, 2004.
Quoted Item No. 2		
M/s Hitachi Energy Pakistan (Pvt) Ltd. Lahore	Non-Responsive	1- As per BDS clause No. 27 of bidding documents, bid indicating delivery beyond 30 days later than specified days set out in schedule-A to bid shall not be considered and rejected as non-responsive. 2- The bidder offered delivery of material 273 days instead of 120 days.


Manager (Procurement)
PMU MEPCO Multan

TECHNICAL EVALUATION REPORT
(As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency: MULTAN ELECTRIC POWER COMPANY LTD, MULTAN
2. Method of Procurement: Single Stage Two Envelop
3. Title of Procurement: For the procurement of Misc. Items (Lot)
4. Tender Inquiry No.: Tender No.32/2023-24
5. PPRA Ref. No. (TSE): TS518027E.
6. Date & Time of Bid Closing: 14.09.2023 at 11:45
7. Date & Time of Bid Opening: 14.09.2023 at 12:15
8. No of Bids Received: Four (04)
9. Criteria for Bid Evaluation: As per bidding document
10. Details of Bid(s) Evaluation: As under:-

Name of Bidder	Technical Marks (if applicable)	Rule/Regulation/SBD*/Policy/ Basis for Technical Rejection / Acceptance as per Rule 35 of PP Rules, 2004.
Quoted item No. 05,10-17, 22, 28-30, 32 & 33.		
M/s Ikram Corporation (Pvt) Ltd. Lahore	Responsive	
Quoted item No. 16, 18, 19, 20, 21, 25, 28, 29 & 31.		
M/s Q.C.C. (Pvt) Ltd. Multan	Responsive	
Quoted item No. 04-05, 07-09, 11-14 & 16-33.		
M/s Shah Gee Enterprises Lahore	Responsive Item No. 4-5, 8-9, 12,14,16-21,25-28 & 30-33	
	Non-Responsive Item No. 07, 11, 13, 22- 24 & 29	7- Bidder failed to provide requisite test report of offered transformer oil. 11- Bidder has not quoted any model against hydraulic press machine. 13- Bidder has not quoted any model against hydraulic cutter. 22- Bidder has not quoted any model against binocular. 23- Quoted model does not indicate lowest range 24- Bidder has quoted model YDQ-II having maximum voltage level upto 110KV instead of 132KV. 29- Prototype approval expired in 30.03.23.
Quoted item No. 01-03, 06-07, 22-23 & 28.		
M/s M.N Enterprises Lahore	Responsive 1-3, 6, 22-23 & 28	
	Non Responsive Item No. 7	Bidder failed to provide requisite test report of offered transformer oil.


Manager (Procurement)
PMU MEPCO Multan.