

TECHNICAL EVALUATION REPORT
(As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency: MULTAN ELECTRIC POWER COMPANY LTD, MULTAN
2. Method of Procurement: Single Stage Two Envelop
3. Title of Procurement: For the procurement of 11KV Capacitor Units
4. Tender Inquiry No.: Tender No. 06/2023-24
5. PPRA Ref. No. (TSE): TS516330E.
6. Date & Time of Bid Closing: 20.09.2023 at 11:45
7. Date & Time of Bid Opening: 20.09.2023 at 12:15
8. No of Bids Received: Four (04)
9. Criteria for Bid Evaluation: As per bidding document
10. Details of Bid(s) Evaluation: As under:-

Name of Bidder	Technical Marks (if applicable)	Rule/Regulation/SBD*/Policy/ Basis for Technical Rejection / Acceptance as per Rule 35 of PP Rules, 2004.
M/S Shah Gee Enterprises (Pvt) Ltd. Lahore	Technically Non-Responsive	Due to following Reasons:- 1- Offered Bus Bar Insulator has technical deviation in length and creepage distance. 2- The bidder has attached authorization letter of M/s Shijiazhuang Fayun Electri Co. Ltd. China for the supply of fuse holder only instead of Fuse Rod with holder for 200KVAR Capacitor.
M/s Mighty Corporation Lahore	Technically Non-Responsive	Due to non-provision of detail of all pending litigation arbitration and other claims whether pending threatened or resolved in last five years
M/s SSI Engineering (Pvt) Ltd. Lahore	Technically Non-Responsive	Due to non-provision of any supporting documents in support of 70% supply of tendered material having similar or higher rating during last five years in single or multiple contracts and not submitted in the prescribed format given in standard forms of bidding documents.
M/s Black Steel International Lahore	Technically Non-Responsive	Due to following Reasons:- 1- Offered 11KV Capacitor has provision of Internal Fuse which is contrary to NTDC Specifications P-78:2010 having clause 1.1 (Technical Deviation) 2- The bidder has not attached 02 Nos. satisfactory operational certificates of offered capacitor. 3- Type Test Report of 11KV Capacitor Units 200KVAR having type BAM 12/V3-200-1W attached with the bid is not acceptable as the type tests were carried out on internal fuse capacitor instead of external fuse.


Addl. Chief Engineer (Procurement)
PMU MEPCO Multan.

TECHNICAL EVALUATION REPORT
(As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency: MULTAN ELECTRIC POWER COMPANY LTD, MULTAN
2. Method of Procurement: Single Stage Two Envelope
3. Title of Procurement: For the procurement of 11KV Panels
4. Tender Inquiry No.: Tender No. 14/2023-24
5. PPRA Ref. No. (TSE): TS516328E.
6. Date & Time of Bid Closing: 17.08.2023 at 11:00
7. Date & Time of Bid Opening: 17.08.2023 at 11:30
8. No of Bids Received: One (01)
9. Criteria for Bid Evaluation: As per bidding document
10. Details of Bid(s) Evaluation: As under:-

Name of Bidder	Technical Marks (if applicable)	Rule/Regulation/SBD*/Policy/ Basis for Technical Rejection / Acceptance as per Rule 35 of PP Rules, 2004.
M/s PEL (Pvt) Ltd. Lahore	Technically Non -Responsive	Due to non-provision of unconditional undertaking duly signed and stamped in connection with clause 2.5 (i-iii) of revised NTDC Type Test Policy 2022 for prototype approval as per NTDC Specification P-44:2018 amended upto date


Addl. Chief Engineer (Procurement)
PMU MEPCO Multan.

TECHNICAL EVALUATION REPORT
(As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency: MULTAN ELECTRIC POWER COMPANY LTD, MULTAN
2. Method of Procurement: Single Stage Two Envelop
3. Title of Procurement: For the procurement of Fire Fighting Equipment
4. Tender Inquiry No.: Tender No.33/2023-24
5. PPRA Ref. No. (TSE): TS518027E.
6. Date & Time of Bid Closing: 14.09.2023 at 12:00
7. Date & Time of Bid Opening: 14.09.2023 at 12:30
8. No of Bids Received: Two (02)
9. Criteria for Bid Evaluation: As per bidding document
10. Details of Bid(s) Evaluation: As under:-

Name of Bidder	Technical Marks (if applicable)	Rule/Regulation/SBD*/Policy/ Basis for Technical Rejection / Acceptance as per Rule 35 of PP Rules, 2004.
M/S Q.C.C. (Pvt) Ltd. Multan	Technically Non-responsive	Due to non-provision of complete technical data of tendered material as per relevant NTDC/WAPDA Specification.
M/S Modern Anti Fire Corporation Lahore	Technically Responsive	---


Addl. Chief Engineer (Procurement)
PMU MEPCO Multan