

SHUT DOWNS ON 132KV TRANSMISSION LINES / GRID STATIONS

I.R.O GSO CIRCLE MEPCO SAHIWAL FOR 03/2024

Sr. No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effectuated Area	Safety Supervisor
					From	To			
1	MEPCO	220KV Vehari/ 20/26MVA, 132/11KV P/TF T-4	04.03.24	Monday	8:00	12:00	To replace the 11KV incoming panel	11 KV O/G Faisal Town, Khalil Shaheed, Piply feeders	Obaid Ullah (AET Vehari) 0302-8290667
2	MEPCO	220KV Vehari/ 20/26 MVA, 132/11KV P/TF T-5	04.03.24	Monday	8:00	12:00	For Safety purpose	11 KV O/G Jungle Buryali, 24/W.B. Akram Shaheed feeders	Obaid Ullah (AET Vehari) 0302-8290667
3	MEPCO	132KV Ludden/ 132KV Bus Bar controlled by 132KV CB LDN-1 - LDN-2 - LDN-3 - LDN-4	05.03.24	Tuesday	8:00	12:00	To attend the hot spot points pointed out during thermovision	Whole area of 132KV G/S Ludden & Karam Pur (11KV O/G Ludden, Firdous, Sajwar Shaheed, Farooq Shaheed, Ahmad Abad, Dolat Abad, Nadir Wali, Shams Abad, Head Islam, Aftab Mehmood, Tipu, Muhammad Shah, Hassan Shah, Zia Shaheed, Karam Pur, Tabark Wah & Idrees Shaheed feeders)	Abdul Rahman (AEM Vehari) 0335-0267728
4	MEPCO	132KV G/S Mianchannu/132/11KV, 3.15/40 MVA P/TF T-2	05.03.24	Tuesday	9:00	15:00	To Replace 02-No AREVA make deteriorated 11KV panels	11KV O/G City-1, Old Kachakhu, Moshan Wal, New Kachakhu, Chak 2-9R, Hamad Banglow, (06-No feeders)	Muhammad Akram FM Cell # 0302-7892530
5	MEPCO	132KV Hasil Pur-Chuna Wala T/L controlled by 132KV CB HSP-7 - CNW-1	06.03.24	Wednesday	8:00	14:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Chuna Wala (Whole area of 11KV O/G City Chuna Wala, New Cholistan and Al-Fateh feeders)	Fazal Ur Rehman (AET Hasil Pur) 0301-8725937
6	MEPCO	132KV Haroon Abad-Donga Bonga T/L controlled by 132KV CB HRB-5 - DBA-1	06.03.24	Wednesday	8:00	14:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Donga Bonga, (11 KV O/G City Donga Bonga, Rasool Pura Chishti and mohaib ali feeders)	Behzad Ali (AET Bahawal Nagar) 0302-8290668
7	MEPCO	132KV G/S Kachakhu/ 132/11KV, 20/26MVA P/TF T-1	06.03.24	Wednesday	9:00	14:00	To attend the oil leakage of P/TF T-1	10-MW load mangement will be required during shut down	Muhammad Akram FM Cell # 0302-7892530
8	MEPCO	132KV Garha More/ 132/11KV 20/26MVA P/TF T-1	07.03.24	Thursday	8:00	14:00	Major overhauling of OLTC of Power Transformer	11 KV O/G Mitru, Dillu More, Chak Shahana, Basheer Shaheed, Khalid Bin Waleed feeders	Abdul Rahman (AEM Vehari) 0335-0267728
9	MEPCO	132KV Haroon Abad-Faqir Wali T/L controlled by 132KV CB HRB-3 - FQW-1	07.03.24	Thursday	8:00	14:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Faqir Wali, Khichi Wala, Fort Abbas and Marrot. (11 KV O/G City Faqir Wali, Wains, Canal 7R, City-II Faqir Wali, Yateem Wala, Rural, Mehria City, City Fort Abbas, Fort, Ouraish, Rafiq Shaheed, Khichi Wala, Walhar, Rafique Abad, THQ Hospital Fort Abbas, Gafoor Shaheed, City Khichi Wala, 75 Adda, Fazal Shah, Latif Abad, Marrot-I, City Marrot, Mansoor, Cholistan, Zia, Rohi, Sardar, Chappu & Meer Garh feeders)	Behzad Ali (AET Bahawal Nagar) 0302-8290668
10	MEPCO	132KV G/S Sahiwal New/132/11KV, 3.15/40 MVA P/TF T-1	07.03.24	Thursday	8:00	14:00	To attend the fault of Auxiliary changover switch	11KV O/G Civil Hospital, T.V Corporation, College Road, Kourey Shah, Noor Shah, Asiyana Housing Scheme, DHQ Teaching Hospital, Ratti Tibbi feeders	Muhammad Akram FM Cell # 0302-7892530
11	MEPCO	132KV G/S Sahiwal New/ 132/11KV, 20/26MVA P/TF T-2						11KV O/G Ansar, Chak 85, Tariq Bin Zaid, Shadman feeders	