

SHUT DOWNS ON 132KV TRANSMISSION LINES / GRID STATIONS									
I.R.O GSO CIRCLE MEPCO SAHIWAL FOR 04/2024 (NO AREA AFFECT)									
Sr. No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effectuated Area	Safety Supervisor
					From	To			
1	MEPCO	132KV Chichawatni / 132KV Chichawatni-Kassowal New T/L controlled by 132KV CB CCW-1 - KSW-2	15.04.24	Monday	8.30	11.30	Annual maintenance / testing of 132KV CB CCW-1 & Line Isolator No. 101	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
2	MEPCO	132KV Chichawatni/ 132KV Chichawatni-Kassowal 220KV CCT-I T/L controlled by 132KV CB CCW-2 -E9Q1	15.04.24	Monday	11.30	14.30	Annual maintenance / testing of 132KV CB CCW-2 & Line Isolator No. 102	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
3	MEPCO	132KV Arifwala-Yousafwala T/L controlled by 132KV CB ARW-7-E7Q1	15.04.24	Monday	8.30	14.00	To set right the dead end jumpers	No area will be effected due to dual source	Muhammad Nafees LS Cell # 0302-8291776
4	MEPCO	132KV 220KV Kassowal - Mianchannu T/L controlled by 132KV CB E5Q-1- MCN-2	15.04.24	Monday	8.00	13.00	To set right the dead end jumpers	No area will be effected due to dual source	Altat Hussain, LS-I Cell # 0302-8291775
5	MEPCO	132KV Head Sidhna/ 132KV Head Sidhna-Shor Kot T/L controlled by 132KV CB SDN-2-SRC-1	16.04.24	Tuesday	9.00	12.00	Annual maintenance / testing of 132KV CB SDN-2 & Line Isolator No. 102	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
6	MEPCO	132KV Head Sidhna/ 132KV Head Sidhna-Bati Banglow T/L controlled by 132KV CB SDN-1-BT8-2	16.04.24	Tuesday	12.00	15.00	Annual maintenance / testing of 132KV CB SDN-1 & Line Isolator No. 101	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
7	MEPCO	132KV Kameer-Yousafwala T/L controlled by 132KV CB KER-1-E6Q1	16.04.24	Tuesday	8.30	14.00	To set right the dead end jumpers	No area will be effected due to dual source	Muhammad Nafees LS Cell # 0302-8291776
8	MEPCO	132KV Chichawatni - 220KV Kassowal T/L controlled by 132KV CB CCW-4 - E8Q-1	16.04.24	Tuesday	8.00	13.00	To set right the dead end jumpers	No area will be effected due to dual source	Altat Hussain, LS-I Cell # 0302-8291775
9	MEPCO	132KV Lal Sohanra-Hasil Pur T/L controlled by 132KV CB LSR-3- HSP-2	16.04.24	Tuesday	7.00	11:00	Washing/cleaning of disc insulators	No area will be affected due to dual source	Fazal Ur Rehman (AET Hasil Pur) 0301-8725937
10	MEPCO	132KV Noor Ser-Bahawal Nagar T-Off Qabula T/L controlled by 132KV CB NSR-4 - BWN-5 - QBL-2	16.04.24	Tuesday	7:00	11:00	Washing/cleaning of disc insulators	No area will be affected due to dual source.	Behzad Ali (AET Bahawal Nagar) 0302-8290668
11	MEPCO	132KV Mianchannu - Khanewal T/L controlled by 132KV CB MCN-3 - KNN-2	17.04.24	Wednesday	8.00	13.00	To set right the dead end jumpers	No area will be effected due to dual source	Altat Hussain, LS-I Cell # 0302-8291775
12	MEPCO	132KV Fort Abbas/ 132KV C.B FTA-41BC controlling 132KV Capacitor Bank	17.04.24	Wednesday	8:30	14:30	Annual maintenance of 132KV CB FTA-41BC	No area will be affected	Abdul Rahman (AEM Vehari) 0335-0267728
13	MEPCO	132KV Chishtian 220KV-Haroon Abad CCT-II T/L controlled by 132KV CB E6Q1 - HRB-2	17.04.24	Wednesday	7:00	11:00	Washing/cleaning of disc insulators	No area will be affected due to dual source	Fazal Ur Rehman (AET Hasil Pur) 0301-8725937
14	MEPCO	132KV Noor Ser-Bahawal Nagar-II T/L controlled by 132KV CB NSR-1 - BNR-3	17.04.24	Wednesday	7:00	11:00	Washing/cleaning of disc insulators	No area will be affected due to dual source.	Behzad Ali (AET Bahawal Nagar) 0302-8290668
15	MEPCO	132KV Qabula/132KV Qabula-Arifwala T/L, controlled by 132KV CB QBL-1-ARW-2	18.04.24	Thursday	8.30	11.30	Annual maintenance / testing of 132KV CB QBL-1 & Line Isolator No. 101	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
16	MEPCO	132KV Qabula/ 132KV Bahawal Nagar-Noor Ser T-off Qabula T/L, controlled by 132KV CB QBL-2-BWN-5-NSR-4	18.04.24	Thursday	11.30	14.30	Annual maintenance / testing of 132KV CB QBL-2 & Line Isolator No. 102	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
17	MEPCO	132KV Qadirabad-Bunga Hayat T/L, controlled by 132KV CB QDR-4-BGH-1	18.04.24	Thursday	8.30	14.00	To set right the dead end jumpers	No area will be effected due to dual source	Muhammad Nafees LS Cell # 0302-8291776
18	MEPCO	132KV Sahiwal Old - 220KV Kassowal T/L controlled by 132KV CB SHW-4 - E6Q-1	18.04.24	Thursday	8.00	13.00	To set right the dead end jumpers	No area will be effected due to dual source	Altat Hussain, LS-I Cell # 0302-8291775
19	MEPCO	132KV Chishtian/ 132KV C.B CNN-41BC controlling 132KV Capacitor Bank	18.04.24	Thursday	8:00	14:00	Annual maintenance of 132KV CB CNN-41BC	No area will be affected	Abdul Rahman (AEM Vehari) 0335-0267728
20	MEPCO	132KV Vehari 220KV-Ludden T/L controlled by 132KV CB E13Q1-LDN-4	18.04.24	Thursday	8:00	14:00	Set right the jumpers of dead towers	No area will be affected due to dual source.	Obaid Ullah (AET Vehari) 0302-8290667
21	MEPCO	132KV Noor Ser-Bahawal Nagar T/L controlled by 132KV CB NSR-5 - BWN-6	18.04.24	Thursday	8:00	14:00	Washing/cleaning of disc insulators	No area will be affected due to dual source.	Behzad Ali (AET Bahawal Nagar) 0302-8290668
22	MEPCO	132KV Hoota/ 132KV Hoota-Bahawal Nagar T/L controlled by 132KV CB HOT-2-BWN-1	19.04.24	Friday	8.30	11.30	Annual maintenance / testing of 132KV CB HOT-2 & Line Isolator No. 102	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
23	MEPCO	132KV Sahiwal New-Yousafwala CCT-II T/L controlled by 132KV CB SHN-3 - E11Q1	19.04.24	Friday	8.30	14.00	To set right the dead end jumpers	No area will be effected due to dual source	Muhammad Nafees LS Cell # 0302-8291776
24	MEPCO	132KV Makhdoom Pur Pohoran - Kabirwala T/L controlled by 132KV CB MPP-1 - KWB-3	19.04.24	Friday	8.30	14.00	To set right the dead end jumpers	No area will be effected due to dual source	Altat Hussain, LS-I Cell # 0302-8291775

P-01

Sr. No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effectuated Area	Safety Supervisor
					From	To			
25	MEPCO	132KV Khanewal/ 132KV Khanewal-Foji Kabirwala CCT-I T/L controlled by 132KV CB KNW-5-E1Q1	22.04.24	Monday	8.30	11.30	Annual maintenance / testing of 132KV CB KNW-5 & Line Isolator No. 105	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
26	MEPCO	132KV Khanewal/ 132KV Khanewal-Foji Kabirwala CCT-II T/L controlled by 132KV CB KNW-6-E4Q1	22.04.24	Monday	11.30	14.30	Annual maintenance / testing of 132KV CB KNW-6 & Line Isolator No. 106	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
27	MEPCO	132KV Sahiwal-III-Sahiwal New T/L controlled by 132KV CB SHT-1-SHN-4	22.04.24	Monday	8.30	14.00	To set right the dead end jumpers	No area will be effected due to dual source	Muhammad Nafees LS Cell # 0302-8291776
28	MEPCO	132KV Chak 83/12-L - 220KV Kassowal T/L controlled by 132KV CB CHK-2 - E4Q-1	22.04.24	Monday	8.00	13.00	To set right the dead end jumpers	No area will be effected due to dual source	Altaf Hussain, LS-I Cell # 0302-8291775
29	MEPCO	132KV Chishtian 220KV-Bahawal Nagar II T/L controlled by 132KV CB E4Q1 - BNR-1	22.04.24	Monday	7.00	11.00	Washing/cleaning of disc insulators	No area will be affected due to dual source.	Behzad Ali (AET Bahawal Nagar) 0302-8290668
30	MEPCO	132KV Sahiwal New-Yousafwala CCT-I T/L controlled by 132KV CB SHN-2 - E12Q1	23.04.24	Tuesday	8.30	14.00	To set right the dead end jumpers	No area will be effected due to dual source	Muhammad Nafees LS Cell # 0302-8291776
31	MEPCO	132KV Musa Virk - Kacha Khuh T/L controlled by 132KV CB MSV-2 - KKH-1	23.04.24	Tuesday	8.00	13.00	To set right the dead end jumpers	No area will be effected due to dual source	Altaf Hussain, LS-I Cell # 0302-8291775
32	MEPCO	132KV Lal Sohanra-Khair Pur Tomewali T/L controlled by 132KV CB LSR-4 - KPT-1	23.04.24	Tuesday	7.00	11.00	Washing/cleaning of disc insulators	No area will be affected due to dual source	Fazal Ur Rehman (AET Hasil Pur) 0301-8725937
33	MEPCO	132KV Chishtian 220KV-Noor Ser T/L controlled by 132KV CB E3Q1 -NSR-2	23.04.24	Tuesday	7.00	11.00	Washing/cleaning of disc insulators	No area will be effected due to dual source.	Behzad Ali (AET Bahawal Nagar) 0302-8290668
34	MEPCO	132KV Chak 83/12-L/ 132KV Chak 83/12-L-Mianchannu T/L controlled by 132KV CB CHK-1-MCN-4	24.04.24	Wednesday	8.30	11.30	Annual maintenance / testing of 132KV CB CHK-1 & Line Isolator No. 101	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
35	MEPCO	132KV Chak 83/12-L/132KV Chak 83/12-L-Kassowal 220KV T/L controlled by 132KV CB CHK-2-E4Q1	24.04.24	Wednesday	11.30	14.30	Annual maintenance / testing of 132KV CB CHK-2 & Line Isolator No. 102	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
36	MEPCO	132KV Arifwala-Kameer T/L controlled by 132KV CB ARW-6-KER-2	24.04.24	Wednesday	8.30	14.00	To set right the dead end jumpers	No area will be effected due to dual source	Muhammad Nafees LS Cell # 0302-8291776
37	MEPCO	132KV Makhdoom Pur - Bati Bungalow T/L controlled by 132KV CB MPP-2 - BTB-1	24.04.24	Wednesday	8.30	14.00	To set right the dead end jumpers	No area will be effected due to dual source	Altaf Hussain, LS-I Cell # 0302-8291775
38	MEPCO	132KV Chishtian 220KV-Haroon Abad CCT-II T/L controlled by 132KV CB E6Q1 - HRB-2	24.04.24	Wednesday	7.00	11.00	Washing/cleaning of disc insulators	No area will be affected due to dual source	Fazal Ur Rehman (AET Hasil Pur) 0301-8725937
39	MEPCO	132KV Sahiwal Old -Yousafwala T/L controlled by 132KV CB SHW-6 - E10Q1	25.04.24	Thursday	8.30	14.00	To set right the dead end jumpers	No area will be effected due to dual source	Muhammad Nafees LS Cell # 0302-8291776
40	MEPCO	132KV Arifwala/ 132KV Arifwala-Qabula T/L, controlled by 132KV CB ARW-2 - QBL-1	26.04.24	Friday	8.30	11.30	Annual maintenance / testing of 132KV CB ARW-2 & Line Isolator No. 102	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
41	MEPCO	132KV Noor Pur -Yousafwala T/L controlled by 132KV CB NPR-1-E16Q1	26.04.24	Friday	8.30	14.00	To set right the dead end jumpers	No area will be effected due to dual source	Muhammad Nafees LS Cell # 0302-8291776
42	MEPCO	132KV Harappa-Sahiwal Old T/L controlled by 132KV CB HAP-1-SHW-3	26.04.24	Friday	8.00	12.00	To set right the dead end jumpers	No area will be effected due to dual source	Altaf Hussain, LS-I Cell # 0302-8291775
43	MEPCO	132KV Mianchannu / 132KV Mianchannu-Kacha Khuh T/L controlled by 132KV CB MCN-1-KKH-1	29.04.24	Monday	8.30	11.30	Annual maintenance / testing of 132KV CB MCN-1 & Line Isolator No. 101	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
44	MEPCO	132KV Mianchannu / 132KV Mianchannu-Kassowal 220KV T/L controlled by 132KV CB MCN-2-E5Q1	29.04.24	Monday	11.30	14.30	Annual maintenance / testing of 132KV CB MCN-2 & Line Isolator No. 102	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
45	MEPCO	132KV Arifwala-Hoota T/L, controlled by 132KV CB ARW-3 & 101 (HOT)	29.04.24	Monday	8.30	14.00	To set right the dead end jumpers	No area will be effected due to dual source	Muhammad Nafees LS Cell # 0302-8291776
46	MEPCO	132KV Chichawatni - 220KV Kassowal T/L controlled by 132KV CB CCW-2 - E9Q-1	29.04.24	Monday	8.00	13.00	To set right the dead end jumpers	No area will be effected due to dual source	Altaf Hussain, LS-I Cell # 0302-8291775
47	MEPCO	132KV Qabula-Arifwala T/L, controlled by 132KV CB QBL-1-ARW-2	30.04.24	Tuesday	8.30	14.00	To set right the dead end jumpers	No area will be effected due to dual source	Muhammad Nafees LS Cell # 0302-8291776
48	MEPCO	132KV Mianchannu - 220KV Kassowal T/L controlled by 132KV CB MCN-2 - E5Q-1	30.04.24	Tuesday	8.00	13.00	To set right the dead end jumpers	No area will be effected due to dual source	Altaf Hussain, LS-I Cell # 0302-8291775
2	Submitted for approval of shut down in view of above submission, please.								

Bod. 