

Tel : 061-6305545
 Fax: 061-6305546
 No. : 20819-29 /

Office of
 The Chief Executive
 Dated: 13 / 06 / 2025.

Superintending Engr: (GSO) MEPCO Circle Multan.

Subject: APPROVAL OF SHUT DOWN.

Ref. SE GSO MEPCO Circle Multan letter No. 6317-35 dated 05.06.2025.

The shut down as required by you is hereby approved subject to publication in the important news add papers as well as prior information to all important / dedicated consumers duly confirmed in writing and their concurrence. In ition the announcement through loudspeakers of Mosques be made for the information of General Public. *It is also requested to direct SSO Incharge of concerned Grid Station to implement the revised load shedding schedule strictly as directed by worthy GM (Op) MEPCO HQ Multan.*

Sr No	Disco	Namd of Grid Station / Name of Equipment	Date & Time	Purpose Of Shutdown	Effected Area
1	MEPCO	132KV Vehari Road Multan 132KV Bus Bar (Alongwith all line Isolators)	21.06.2025 05:30 To 11:30 (06-Hrs)	For provision of droppers at bus isolators for newly constructed 02No.Line Bays (Extension Work) (AT 132KV G/S Vehari Road Multan)	132KV Vehari Road Sharif Pura 022008, Ansar Colony 022015, Masoom Shah 022004, Tatey Pur 022009, Cricket Stadium 022013, Mehmood Feed 022018, Al-Hilal Industries 022019, S.M.Foods 022021, Jinnah Chowk 022030, New Rashid Road 022027, Muslim Town 022029, Manzoor Abad 022031, Ghous Pura 022017, New Vehari Road 022010, Al-Hilal 022001, Hafiz Jamal 022003, Samejabad 022016, New Multan 022006, Shah Rukn-e- Alam 022011, Gulshan Market 022012, Dehli Gate 022014, Khawaja Fareed Hospital 022020, Fatima Jinnah Colony 022022, D-Market 022023Ali Town 022026, Qureshi 022028, Usman-e-Ghani Road 022025 & Jhock Lashker 022032.
2		132KV T/Line 500KV New Multan - Qasim Pur Multan		For Provision of line isolators droppers to energize the 02No. New line bays (AT 132KV G/S Vehari Road Multan)	132KV Qasim Bagh Arif Pura 076303, Iqbal Nagar 076310, New Hussain Agahi 076309, Nishat Road 076312, City 076305, New Hafiz Jamal 076306, New Dehli Gate 076307, New Manzoor Abad 076308, Tahir Majeed Shaheed 076311, Faisal Pura 076313. 132KV Qasim Pur Approx. 20MW load management will be carried out at 132KV Grid Station Qasim Pur as the same will be fed from MESCO side

NOTE. Mr. Afnan Ahmad LS-II No.0319-9765829 has been declared as Safety Supervisor for this Shutdown as told by XEN GC Div GSC Multan.

It must be ensured that the timings of the shutdown are observed strictly & the electricity supply is restored accordingly.

This issues with the approval of Chief Engineer (O&M) Distn: MEPCO Multan.

Note:- The compensation schedule must be implemented in true spirit as per directions of worthy Chief Engineer (Op) MEPCO HQ Multan.

DA/Schedule of shut down.

**Dy: Manager (O&M) Distn:
MEPCO Ltd, Multan**

- General Manager (Op) MEPCO HQ Multan for information along with Compensation schedule in load shedding programme please.
- Chief Engineer (O&M) Distn: for information as desired please.
- CE NPCC Islamabad / Director RCC Jamshoro for information please.
- S.F. (OP) MEPCO Multan w.r to his letter No 44051-55 dated 13.06.2025 with Compensation schedule in load shedding programme as received from your office with the request to implement the schedule.
- Director (IT) MEPCO Multan for necessary action & uploading on website, please.
- XEN (OP) M/Pak, SR Alam, City & M/abad Div with the advise to carry out Maintenance works on the said feeders during this approved shut down as desired by Competent Authority.
- Dy: Manager M.P.C.C MEPCO Multan along with Compensation schedule in load shedding programme for Implementation & also to inform PITC & load on Roshan Pakistan app. pl.
- Dy: Manager R.C Cell for information and necessary action.
- Addl: Manager (P.R) MEPCO H/Q Multan with the advice to arrange Publication in newspapers & announcement through Electronic media & send the press cutting of above shut down.
- Mr. Ameer Hamza SSO-I/ Safety Inspector (HSE) with the directions to monitor the above shut down and ensure the Implementantion of all Safety measures in true letter & Spirit as per MEPCO SOP.