

MULTAN ELECTRIC POWER COMPANY (MEPCO)

Tel : 061-6305545

Fax : 061-6305546

No. : 1724-34/1

Office of

The Chief Executive

Dated: 04/08/2025.

Superintending Engr: (GSO) MEPCO Circle Sahiwal.

Subject: APPROVAL OF SHUT DOWN.

Ref. SE GSO MEPCO Circle Sahiwal letter No. 4868-76 dated 31.07.2025.

The shut down as required by you is hereby approved subject to publication in the important news add papers as well as prior information to all important / dedicated consumers duly confirmed in writing and their concurrence. In ition the announcement through loudspeakers of Mosques be made for the information of General Public. *It is also requested to direct SSO Incharge of concerned Grid Station to implement the revised load shedding schedule strictly as directed by worthy GM (Op) MEPCO HQ Multan.*

Sr No	Disco	Namd of Grid Station / Name of Equipment	Date & Time	Purpose Of Shutdown	Effected Area
1	MEPCO	132KV Faqir Wali - Khichi Wala T/L controlling 132KV CBs FQW-4 - KHW-1	05.08.2025 06.08.2025 09.08.2025 11.08.2025 07:00 To 13:00 (06-Hrs Daily)	Stringing of 132KV Faqir wali - khichi wala Fort abbas CCT-II T/L from Tower No. 50-60 (safety purpose for existing Circuit)	Whole area of 132KV G/S Khichi Wala, Fort Abbas and Marrot. 027601 City Fort Abbas, 027605 Fort, 027602 Quraish, 027607 Rafiq Shaheed, 027603 Khichi Wala, 027604 Walhar, 027606 Rafique Abad, 027608 THQ Hospital Fort Abbas, 120803Gafoor Shaheed, 120805 City Khichi Wala, 12080275 Adda, 120801 Fazal Shah, 120804 Latif Abad, 060601 Marrot-I, 060602City Marrot, 060603 Mansoor, 060604 Cholistan, 060605 Zia, 060606 Rohi, 060607 Sardar, 060608 Chappu & 060609 Meer Garh feeders
2		132KV Faqir Wali - Khichi Wala T/L controlling 132KV CBs FQW-4 - KHW-1	12.08.2025 13.08.2025 07:00 To 15:00 (08-Hrs Daily)	Tower erection and In-Out Circuit Khichi Wala (safety purpose for existing Circuit)	

NOTE.Mr. Shehbaz Ali LS-II No. 0319-9765912 & Tajammal Hussain LS-II No.0319-9765893 has been declared as Safety Supervisor for this Shutdown as told by XEN T&G "C" Divn GSC MEPCO.

It must be ensured that the timings of the shutdown are observed strictly & the electricity supply is restored accordingly.

This issues with the approval of Chief Engineer (O&M) Distn: MEPCO Multan.

Note:- The compensation schedule must be implemented in true spirit as per directions of worthy Chief Engineer (Op) MEPCO HQ Multan.

DA/Schedule of shut down.

C.C.


Dy: Manager (O&M) Distn:
MEPCO Ltd. Multan

- 1- General Manager (Op) MEPCO HQ Multan for information along with Compensation schedule in load shedding programme please.
- 2- Chief Engineer (O&M) Distn: for information as desired please.
- 3- CE NPCC Islamabad / Director RCC Jamshoro for information please.
- 4- S.E. (OP) MEPCO B/Nagar w.r. to his letter No. 14797-806 dated 31.07.2025 with Compensation schedule in load shedding programme as received from your office with the request to implement the schedule.
- 5- Director (IT) MEPCO Multan for necessary action & uploading on website, please.
- 6- XFN (Op) MEPCO Haroon abad Div with the advise to carry out Maintenance works on the said feeders during this approved shut down as desired by Competent Authority.
- 7- Dy: Manager M.P.C.C MEPCO Multan along with Compensation schedule in load shedding programme for Implementation & also to inform PITC & load on Roshan Pakistan app. pl.
- 8- Dy: Manager R.C Cell for information and necessary action.
- 9- Addl: Manager (P.R) MEPCO H/Q Multan with the advice to arrange Publication in newspapers & announcement through Electronic media & send the press cutting of above shut down.
- 10- Mr Ameer Hamza SSO-I/ Safety Inspector (HSE) with the directions to monitor the above shut down and ensure the Implementantion of all Safety measures in true letter & Spirit as per MEPCO SOP.