

FINAL EVALUATION REPORT
(As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency: MULTAN ELECTRIC POWER COMPANY LTD, MULTAN
2. Method of Procurement: Single Stage Two Envelope
3. Title of Procurement: For the procurement of 145-KV SF-6 Gas Circuit Breakers
4. Tender Inquiry No.: Tender No. 01/2025-26
5. PPRA Ref. No. (TSE): TS595355E.
6. Date & Time of Bid Closing: 31.07.2025 at 11:00
7. Date & Time of Bid Opening: 31.07.2025 at 11:30
8. No of Bids Received: Three (03)
9. Criteria for Bid Evaluation: As per Bidding document
10. Details of Bid(s) Evaluation: As under:

Name of Bidder	Marks		Evaluated Cost (PKR)	Rule/Regulation/SBD*/Policy/ Basis for Rejection / Acceptance as per Rule 35 of PP Rules, 2004.
	Technical (if applicable)	Financial (if applicable)		
M/s Siddique Sons Engineering (Pvt) Ltd Lahore	Responsive	Responsive	506,000,000	-----
M/s Wind Ringe Construction (WRC) Company/ M/s M.J Corporation Lahore (JV)	Non-Responsive	---	----	Technically non-Responsive for supply of 145-KV SF-6 Gas Circuit Breakers (03-Poles operated) with SSS having Model OFPI-145-40L-FAR3 Manufactured by M/s Chung-Hsin Electric & Machinery Mfg. Corp. China as the bidder failed to provide performance Certificates of offered Circuit Breakers & non-conduction of Di-Electric Tests from STL Lab.
M/s Global Technologies (Pvt) Ltd Lahore	Responsive	Responsive	537,096,000	-----

Most Advantageous Bidder: M/s Siddique Sons Engineering (Pvt) Ltd Lahore.


Manager (Procurement)
PMU MEPCO Multan