

TECHNICAL EVALUATION REPORT
(As Per Rule 35 of PP Rules, 2004)

1. Name of Procuring Agency: MULTAN ELECTRIC POWER COMPANY LTD, MULTAN
2. Method of Procurement: Single Stage Two Envelope
3. Title of Procurement: For the procurement of 145KV PT with SSS
4. Tender Inquiry No.: Tender No. 08/2025-26
5. PPRA Ref. No.(TSE): TS617411E.
6. Date & Time of Bid Closing: 11.09.2025 at 11:15
7. Date & Time of Bid Opening: 11.09.2025 at 11:45
8. No of Bids Received: Three (03)
9. Criteria for Bid Evaluation: As per bidding document
10. Details of Bid(s)Evaluation: As under:-

Name of Bidder	Technical Marks (if applicable)	Rule/Regulation/SBD*/Policy/ Basis for Technical Rejection / Acceptance as per Rule 35 of PP Rules, 2004.
M/s Siddique Sons Engineering (Pvt) Ltd Lahore	Non-Responsive (Lot-I & Lot-II)	The bidder is non-Responsive in (Lot-I & Lot-II) as per BDS Clause 10 (6) litigation History, section-III of Bidding documents because the litigation amount of bidder is more than 50% of Net worth.
M/s PARAS Trading Company Karachi-M/s Seven Star Company Karachi (JV)	Responsive (Lot-I & Lot-II)	-----
M/s EMCO Industries Ltd Lahore	Non-Responsive (Lot-I & Lot-II)	Technically non-Responsive in (Lot-I & Lot-II) due to the following reasons:- 1. The bidder has failed to provide at least 02-No. performance certificates alongwith relevant purchase orders of offered 145KV PT (GTI-145) as per BDS clause 10 (3), section -III of bidding documents. 2. The bidder neither provided test report of Chopped impulse voltage withstand test on primary terminals; nor submitted undertaking for conduction of missing type test which is required in clause 3, Part-II of NTDC Type test policy 2022.


Manager (Procurement)
PMU MEPCO Multan.