

Tel : 061-6305545
Fax: 061-6305546
No. : 9865-76 / 1

Office of
The Chief Executive
Dated: 30/12/2025

**Superintending Engr: (GSO)
MEPCO Circle Sahiwal.**

Subject: APPROVAL OF SHUT DOWN.

Ref. SE GSO MEPCO Circle Sahiwal letter No. 8363-75 dated 19.12.2025.

The enclosed shut downs as required by you is hereby approved subject to publication in the important newspapers as well as prior information to all important / dedicated consumers duly confirmed in writing and their concurrence. In addition the announcement through loudspeakers of Mosques be made for the information of General Public. *It is also requested to direct SSO Incharge of concerned Grid Station to implement the revised load shedding schedule strictly as directed by worthy GM (Op) MEPCO HQ Multan.*

NOTE: All Safety Supervisor Names and Nos enclosed / Atteched all Copies of this shut downs as told by SE GSO Sahiwal.

It must be ensured that the timings of the shutdown are observed strictly & the electricity supply be restored accordingly.

This issue with the approval of Chief Engineer (O&M) Distn. MEPCO Multan.

Note:- The compensation schedule must be implemented in true spirit as per directions of worthy Chief Engineer (Op) MEPCO HQ Multan.

DA/Schedule of shut down.

P=01 TO 13

C.C.

21/10/2025
**(Dy: Manager (O&M) Distn:
MEPCO Ltd. Multan**

- 1- General Manager (Op) MEPCO HQ Multan for information along with Compensation schedule in load shedding programme please.
- 2- Chief Engineer (O&M) Distn: for information as desired please.
- 3- CE NPCC Islamabad / Director RCC Jamshoro for information please.
- 4- S.E. (OP) MEPCO MEPCO Sahiwal, Vehari, Khanewal, B/Nagar & B/pur w.r. to their letter No.24729-35 Dated 24.12.2025 No.21637 dated 23.12.2025; No.87879-86 dated 26.12.2025, No.24938-52 Dated 22.12.2025 & No.25283-86 Dated 24.12.2025 with Compensation schedule in Load shedding programme as received from your office with the request to implement the schedule.
- 5- Director (IT) MEPCO Multan for necessary action & uploading on website, please.
- 6- Dy.Manager (O&M) T&G for information as desired please.
- 7- All XENs under (Op) Circles Sahiwal, Vehari, Khanewal, B/Nagar & B/pur MEPCO Div with the advise to carry out Maintenance works on the said feeders during this approved shut down as desired by Competent Authority.
- 8- Dy: Manager M.P.C.C MEPCO Multan along with Compensation schedule in load shedding programme for Implementation & also to inform PITC & load on Roshan Pakistan app. pl.
- 9- Dy: Manager R.C Cell for information and necessary action.
- 10- Addl: Manager (P.R) MEPCO H/Q Multan with the advice to arrange Publication in newspapers & announcement through Electronic media & send the press cutting of above shut down.
- 11- Mr.Ameer Hamza SSO-I/ Safety Inspector (HSE) with the directions to monitor the above shut down and ensure the Implementation of all Safety measures in true letter & Spirit as per MEPCO SOP.

SHUT DOWNS ON 132KV TRANSMISSION LINES / GRID STATIONS (AREA EFFECTED)

I.R.O GSO CIRCLE MEPCO SAHIWAL FOR 01/2026

Sr. No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effectuated Area	Safety Supervisor
					From	To			
1	MEPCO	132KV Bahawal Nagar-II/ 132/11KV 10/13 MVA P/T/F T-1	05.01.26	Monday	9:30	15:30	Annual Maintenance/testing	11 KV O/G 119702 Industrial, 119703 Rasheed Shahhead and 119705 Islam Shahhead, New Dream City Housing Scheme feeders	Abdul Rahman (AEM Vehan) 0319-9765644
2	MEPCO	132KV Kehror Pacca-Dunya Pur T/L controlled by 132KV CB KRP-1 & 101	05.01.26	Monday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Dunya Pur 098201 Ali Sher, 098202 Thahia Road, 098206 Sadat, 098208 Khushi Muhammad, 098209 City Noor Peer, 098210 Ghulam Rasool, 098203 Jallian, 098207 City Dunya Pur, 098204 Qutab Pur, 098205 Nasrullah Tarin, 098211 Model Town & 098212 Sadiq Shahhead, THQ Dunya Pur feeders	Obaid Ullah (AET Vehan) 0319-9765641
3	MEPCO	132KV Hasil Pur-Chuna Wala T/L controlled by 132KV CB HSP-7 - CNW-1	05.01.26	Monday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Chuna Wala 077301 City Chuna Wala, 077302 New Cholistan and 077303 Al-Fateh feeders	Behzad Ali (AET Hasil Pur) 0319-9765642
4	MEPCO	132KV Mianchannu / 132/11KV, 20/26MVA P/T/F T-4	06.01.26	Tuesday	9:00	15:00	Annual maintenance / protection testing	11KV O/G J.T.M (013313), Q.T.M (013307), M.T.M (013314) [02-No feeders]	Muhammad Akram FM Cell # 0302-7892530
5	MEPCO	132KV Bahawal Nagar-II/ 132/11KV 10/13 MVA P/T/F T-2	06.01.26	Tuesday	8:00	14:00	Annual Maintenance/testing	11 KV O/G 119707 Bala Arain, 119706 Jhanjran Waili, 119704 Christian Road, 119701 Nazeer Shahhead feeders	Abdul Rahman (AEM Vehan) 0319-9765644
6	MEPCO	132KV Bahawal Nagar II-Minchin Abad T/L controlled by 132KV CB BNR-2 - MNA-1	06.01.26	Tuesday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Minchin Abad & Meccled Gunj 054504 Fidal Shah, 054502 City Minchin Abad, 054505 Railway Road, 054506 Farooq Shahhead, 054503 Mahmood, 054501 PPN Road, 032705 M/Gunj, 054507 M.S.G Road, 032704 M.Abad-II, 032706 Anwar Shahhead, 032707 Al-Mushiaq, 032702 City, 032701 Annaka, 032703 M/Abad/1 & 032708 Head Sulemanki feeders	Behzad Ali (AET Bahawal Nagar) 0319-9765643
7	MEPCO	132KV Sheikh Fazal / 132/11KV, 20/26MVA P/T/F T-1	07.01.26	Wednesday	9:00	15:00	Annual maintenance / protection testing	1KV O/G Ghazi (053605), Sheikh Fazal (053602), Saleem Shahhead (053611), Aft Shah (053608) [04-No feeders] (11 KV O/G 092703 Shah Pur, 092706 Sohail Pur, 092705 Ali Pur, 092716 Mehar Shah, 092710 Anayat Ali, 092720 Mangwani, 092704 Qadir Pur Cheema, 092713 Burhan Pur feeders)	Muhammad Akram FM Cell # 0302-7892530
8	MEPCO	132KV Kehror Pacca/ 132/11KV 31.5/40MVA P/T/F T-3	07.01.26	Wednesday	9:00	15:00	Annual Maintenance/testing	Whole area of 66KV G/S Station Bukhsan Khan and Chishtian 025302 Madrasa, 025307 Main Bazar, 025306 Park, 025308 Gulshan, 115101 City-I Bukhsan Khan, 115103 Syadan Wala & 115102 City-II Bukhsan Khan	Abdul Rahman (AEM Vehan) 0319-9765644
9	MEPCO	66KV Hasil Pur-Chishtian T/L controlled by 66KV CB HSP-5 - CHN-1	07.01.26	Wednesday	9:00	15:00	Washing/cleaning of disc insulators		Behzad Ali (AET Hasil Pur) 0319-9765642

No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
10	MEPCO	132KV Faqir Wali-Fort Abbas T/L controlled by 132KV CB FQW-4 - FTA-1	07.01.26	Wednesday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Fort Abbas and Marrot. 027601 City Fort Abbas, 027605 Fort, 027602 Quraish, 027607 Rafiq Sharheed, 027603 Khichi Wala, 027604 Walhar, 027606 Rafique Abad, 027608 THQ Hospital Fort Abbas, 060601 Marrot-I, 060602 City Marrot, 060603 Mansooria, 060604 Cholistian, 060605 Zia, 060606 Rohi, 060607 Sardar, 060608 Chappu & 060609 Meer Garh feeders	Behzad Ali (AET Bahawal Nagar) 0319-9765643
11	MEPCO	132KV Kachakhul/ 132/11KV, 3, 15/40 MVA P/TF T-3	08.01.26	Thursday	9:00	15:00	Annual maintenance / testing	11KV O/G Chak 29/10-R (008802), Chak 103/15-L (008809), Chak 88/15-L (008810), Chak 24/10-R (008811), J.K. Super Mill (008812), Chak 135 (008814), Chak 42/20-R (008816), Chab Banglow (008817) <u>108-No Feeders</u>	Muhammad Akram Foreman Cell # 0302-7892530
12	MEPCO	132KV Chishtian/132/11KV 20/26 MVA P/TF T-2	08.01.26	Thursday	9:00	15:00	Annual Maintenance/testing	11 KV O/G 072807 City-1st, 072812 Azeem Wan, 072813 THQ Hospital, 072814 3 Maria Housing Scheme, 072816 Saliu, 072817 Fareed Koi, 072802 Mohar Sharif, 072818 Gul Shah feeders	Abdul Rahman (AEM Venar) 0319-9765644
13	MEPCO	132KV Haroon Abad-Donga Bonga T/L controlled by 132KV CBS HRB-5 - DBA-1	08.01.26	Thursday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Donga Bonga 130302 City Donga Bonga, 130301 Rasool Pura, 130304 Munib Ali, 130303 Chisht feeders	Behzad Ali (AET Bahawal Nagar) 0319-9765643
14	MEPCO	132KV Khichi Wala/ 132/11KV 10/13MVA P/TF T-1	10.01.26	Saturday	8:30	13:00	Annual Maintenance/testing	11 KV O/G 120803 Gharfor Sharheed & 120805 City Khichi Wala feeders	Abdul Rahman (AEM Venar) 0319-9765644
15	MEPCO	132KV Khichi Wala/ 132/11KV 10/13MVA P/TF T-2	10.01.26	Saturday	13:30	18:00	Annual Maintenance/testing	11 KV O/G 120802 75 Adda, 120801 Fazal Shah, 120804 Latif Abad feeders	Abdul Rahman (AEM Venar) 0319-9765644
16	MEPCO	132KV Grid Station Bati Banglow / 132/11KV, 10/13MVA P/TF T-2	12.01.26	Monday	9:00	15:00	Annual maintenance / protection testing	11KV O/G Fareed Pur (109305) (01-No Feeder)	Muhammad Akram FM Cell # 0302-7892530
17	MEPCO	132KV Meclod Guni/ 132/11KV 20/26 MVA P/TF T-1	12.01.26	Monday	9:30	15:30	Annual Maintenance/testing	11 KV O/G 032705 M/Guni, 032704 M/Abad-II, 032706 Anwar Sharheed, 032707 AL Mushaq feeders	Abdul Rahman (AEM Venar) 0319-9765644
18	MEPCO	132KV Minchin Abad-Meclod Guni T/L controlled by 132KV CB MNA-2 - MLG-1	12.01.26	Monday	9:00	13:00	Annual Maintenance/testing of 132KV CB MLG-1, 132KV Bus bar and Washing/cleaning of disc insulators	Whole area of 132KV G/S Meclod Guni 032705 M/Guni, 054507 M.S.G Road, 032704 M/Abad-II, 032706 Anwar Sharheed, 032707 AL-Mushaq, 032702 City, 032701 Annuka, 032703 M/Abad-I & 032708 Head Sulemanki feeders	Behzad Ali (AET Bahawal Nagar) 0319-9765643

Food /

No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
19	MEPCO	132KV Chishtian 220KV-Dahran Wala T/L controlled by 132KV CB ESQ1 - DNWV-1	12.01.26	Monday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Dahran Wala 026102 City Chuna Wala, 026103 Bukhsan Khan, 026105 Al Gazli, 026107 Al Fateh, 026106 AL Murad, 026104 Shahheed Chowk and 026101 City Dahran Wala feeders	Behzad Ali (AET Hasil Pur) 0319-9765642
20	MEPCO	132KV Sahuka /132/11KV, 20/26MVA PTFE-T-1	13.01.26	Tuesday	9:00	15:00	Annual maintenance / protection testing	11KV O/G Sadat (053709), Umar Pur (053703), Al-Abas (053705), Murad Ali (053707), Darbar Muhammad Ali (053713) [05-No feeders]	Muhammad Akram Foreman Cell # 0302-7892530
21	MEPCO	132KV Bahawal Nagar/ 132KV bus bar controlled by 132KV CBS BWN-1, BWN-5, BWN-6	13.01.26	Tuesday	8:00	14:00	Annual Maintenance of 132KV bus bar	Whole area of 132KV G/S Bahawal Nagar (11KV/000904 QT Mill, 000905 Scarp-D, 000903 City, 000916 Din Pur Sharaf, 000911 Nizam Pura, 000906 Malik Pura, 000907 Scarp FM, 000909 Jall Wala, 000902 O/Road, 000908 City-II, 000910 Cant, 000912 Hospital, 000921 Qaiser Shahheed, 000919 New City Housing Scheme, 000915 Dist. Jail, 000901 Canal, 000917 Adda Khiraj Pura, 000918 Nawab Sadq, 000920 Ibrahim Shahheed, 000922 Star City, 000923 Ahmad Hasan Rice Mills feeders)	Abdul Rahman (AEM Venah) 0319-9765644
22	MEPCO	66KV Hasil Pur-Chishtian T/L controlled by 66KV CB HSP-5 - CHN-1	13.01.26	Tuesday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 66KV Grid Station Bukhsan Khan and Chishtian 025302 Madrassa, 025307 Main Bazar, 025306 Park, 025308 Gulshan, 115101 City-I Bukhsan Khan, 115103 Syadan Wala & 115102 City-II Bukhsan Khan	Behzad Ali (AET Hasil Pur) 0319-9765642
23	MEPCO	132KV Burewala Old/ 132KV Burewala Old-Burewala T/L, controlled by 132KV CB BWO-1-BRW-3	14.01.26	Tuesday	9:00	12:00	Annual maintenance / testing of 132KV CB BWO-1	11KV O/G Chous Pak (098911), Sharif Shahheed (098912), Madina Colony (098906), B&R (098901), Fatah Shah (098909), Dewan Sahib (098907), Habib Colony (098910), & Khair Wala (098909) [08-No feeders] Burewala Old 11KV O/G Sadat (053709), Umar Pur (053703), Al-Abas (053705), Murad Ali (053707), Darbar Muhammad Ali (053713), Jamliya (053706), Sahuka (053702), Saidara (053704), Sarwar Shah (053708), Haji Sher (053707), Jodhaka (053710), Subhan Shah (053711) & Yousaf Shahheed [12-No feeders Sahuka]	Muhammad Akram FM Cell # 0302-7892530

P=03

No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Affected Area	Safety Supervisor
					From	To			
24	MEPCO	132KV Burewala Old/ 132KV Burewala Old-Sahnuka T/L, controlled by 132KV CB BWO-2-SKA-1	14.01.26	Tuesday	12.00	15.00	Annual maintenance / testing of 132KV CB BWO-2	11KV O/G Sadat (053709), Umar Pu (053703), Al-Abas (053705), Murad Ali (053707), Darbar Muhammad Ali (053713), Jamla (053706), Sahnuka (053702), Saldara (053704), Sawar Shah (053708), Haili Sher (053701), Jodhaka (053710), Subhan Shah (053711) & Yousef Shabeeh (053712) [13-No feeders Sahnuka]	Muhammad Akram FM Cell # 0302-7892530
25	MEPCO	132KV Burewala Old/ 132KV Bus Bar controlled by 132KV CBs BWO-1 - BWO-2 along with T/Lines	14.01.26	Tuesday	9.00	15.00	Annual maintenance of 132KV Bus Bar and line isolator No. 101, 102, 11KV Bus Coupler and tightening of all power cables as well as jumpers & droppers	11KV O/G Ghous Pak (098911), Shaifq Shabeeh (098912), Madina Colony (098906), B&R (098901), Felah Shah (098908), Dewan Sahib (098907), Habib Colony (098910), & Khar Wala (098909) [08-No feeders Burewala Old] 11KV O/G Sadat (053709), Umar Pu (053703), Al-Abas (053705), Murad Ali (053707), Darbar Muhammad Ali (053713), Jamla (053706), Sahnuka (053702), Saldara (053704), Sawar Shah (053708), Haili Sher (053701), Jodhaka (053710), Subhan Shah (053711) & Yousef Shabeeh (053712) [13-No feeders]	Muhammad Akram FM Cell # 0302-7892530 Altair Hussain, LS-I Cell # 0319-9765744
26	MEPCO	132KV Chishtian/132/11KV 20/26 MVA P/TF T-3	14.01.26	Wednesday	9.00	15.00	Annual Maintenance/testing	11 KV O/G 072810 Sallie Town, 072804 Shourae Elahi, 072806 Sher Fareed, 072809 Galan, 072805 Gajlani feeders	Abdul Rahman (AEM Vahan) 0319-9765644
27	MEPCO	132KV Harappa/132KV Bus bar controlled by 132KV CBs HAP-1 & HAP-2 along with T/Lines	15.01.26	Thursday	8.30	15.30	Annual maintenance of 132KV Bus Bar and line isolator No. 101 & 102 along with 11KV Bus coupler & Tightening of 11KV power cables	11KV O/G City (005801), Jimnah Town (005807), Nai Wala (005804), Khaki Shah (005812), Tareen Cold Storage (005811), Ahsan Abad (005813), Shoaib Suleman Mills U-2 (005814), Eden Milk U-2 (005815), Raw (05816), Adams Cold Storage (005817), Kool Wala (005818), Man Textile Mills Harappa (005819), Sahwal Road (005809), Harappa Textile Mill (005803), Shah Murad (005805), S.S.T Mill (005808), Ganji Bar (005802), Suraj Fertilizer (005809), Sadia Feed Mills (005810) [19-No feeders]	Muhammad Akram FM Cell # 0319-9765770 M. Nafees, LS-I Cell # 0319-9765678
28	MEPCO	132KV Haroon Abad/ 132/11KV 31.5/40MVA P/TF T-1	15.01.26	Thursday	9.00	15.00	Annual Maintenance/testing	11 KV O/G 092412 Gulab Ali, 092408 Banglow Road, 092401 City-I, 092413 Dahran Wala Road, 092415 Canal city feeders	Abdul Rahman (AEM Vahan) 0319-9765644
29	MEPCO	132KV Faqir Wali-Khichi Wala T/L controlled by 132KV CBs FQW-3 - KHW-1	15.01.26	Thursday	9.00	15.00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Khichi Wala 120803 Gafoor Shabeeh, 120805 City Khichi Wala, 120802 75 Adda, 120801 Fazal Shah, 120804 Latif Abad feeders	Bethzad Ali (AET Bahawal Nagar) 0319-9765643

Page 4 of 13

No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
30	MEPCO	132KV Vehari/ 132/11KV 31.5/40MVA PTF T-3	17.01.26	Saturday	8:30	14:30	Annual Maintenance/testing	11 KV O/G 021902 Chak 22/VNB, 021901 Crecent Factory, 021918 Chak 182/E.B., 021923 Defence View, 021924 SS Feeds, 021925 City-III, 021930 Defence View VIP Block, 021928 Madina Colony, 021914 New Chak 37 V/B feeders	Abdul Rahman (AEM Vehari) 0319-9765644
31	MEPCO	132KV Sahiwal Old 132KV Bus Bar No-1 & 2, controlled by 132KV CB's SHW-1, SHW-2, SHW-3, SHW-4, SHW-5, SHW-6 & SHW-7 along with T/Lines	17.01.26	Saturday	8:00	16:00	Annual maintenance of 132KV Bus Bar No. 01 & 02 and line Isolator No. 101, 102, 103, 104, 105, 106 & 107, 11KV Bus Coupler and tightening of all power cables.	11KV O/G Royal Palm (018330), Kashmeer Adibail (018317), Lather Co-Ordinator (018326), M.A. Foods (018327), City-1 (018303), Art Road (018334), Bodi Dhakoo (018322), Khula Art (018323), Mullan Road (018307), P.G.H.S (018336), Industrial Estate (018315), Civil Line (018304), Alwa City-1 (018341), Alwa City-2 (018342), Alwa City-3 (018340), Sohni Dharti (018338), Al-Aman Garded, Dara Rahim (018302), Shadab Town (018332), HISCOL (018333), Bailey Wala (018311), SKA-555 (018331), Colony (018305), Seed Corporation (018310), Azan City Dairy (018306), City-2 (018320), Asad Ullah Pur (018337), Muhammad Pur (018335), Engro Foods (018321), Supreme (018319), Safia Rice (018329) & Adam Milk (018328) (32-No Feeders)	M. Nafees, LS-I Cell # 0319-9765678 Altaf Hussain, LS-I Cell # 0319-9765744
32	MEPCO	132KV Mianchannu/ 132 Bus Bar controlled by 132KV CB MCN-1, MCN-2, MCN-3 & MCN-4 along with line isolator No. 101, 102, 103 & 104 (alongwith circuits)	19.01.25	Monday	9:00	16:00	Annual maintenance of 132KV Bus Bar, 11KV Bus Coupler and line Isolator No. 101, 102, 103 & 104 and tightening of all power cables	11KV O/G Tulamba (013312), Dillon Banglow (013322), Mumdoor (013311), Bura Road (013332), New Kachakhu (013305), Chak 98 (013329) City-5 (013327) City-1 (013309), Old Kachakhu (013306), Moshan Wali (013317), Chak 95 (013315), Chak 2-9R (013330), Hamed Banglow (013326), Chak No. 126 (013332), Rayi (013333), New Kassarwal (013302), City-4 (013323), L.B.H.S (013325), S.P. Mills (013321), Bodha (013320), A.U.P.M (013324), City-2 (013310), Industrial Estate (013318), City-3 (013316), Chak & BR (013331), Chak 13 (013328), Old Kassarwal (013303), J.T.M (013313), Q.T.M (013307), M.T.M (013314) (30-No feeders)	Muhammad Akram FM Cell # 0319-9765770
33	MEPCO	132KV Noor Ser/ 132/11KV 20/26MVA PTF T-1	19.01.26	Monday	9:00	15:00	Annual Maintenance/testing	11 KV O/G 054605 Faqr Shah, 054604 Mugeem Shah, 054601 Abdullah, 054605 Mohar Wali feeders	Abdul Rahman (AEM Vehari) 0319-9765644
34	MEPCO	132KV Bonga Hayat / 132/11KV, 31.5/40MVA PTF T-2	20.01.26	Tuesday	9:30	15:30	Annual maintenance / protection testing	11KV O/G Chak Badli (001701), Qudrat Ullah (001702), Sikandar Chowk (001706), Zubair Feed (01708), Farid Kot (001709), Al-Wardi (001704), Wandela Jangeer (001713) (07-No Feeders)	Muhammad Akram FM Cell # 0302-7892530

Handwritten signature/initials

No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
35	MEPCO	132KV Kehror Pacca/ 132KV Bus Bar controlled by 132KV CB KRP-1, KRP-2, KRP-3 & KRP-4	20.01.26	Tuesday	9:00	15:00	Annual Maintenance of 132KV bus bar	Whole area of 132KV G/S Kehror Pacca and Dunya Pur 11 KV O/G 092714 City-II, 092709 Bukhari Wahn, 092707 Noqabli Wahn, 092715 Saliu, 092719 Tibba Sadat, 092722 Sarfraz Shabheed, 092702 Factory, 092712 Goh Bahar, 092701 City Kehror Pacca, 092711 Faten Shah, 092718 Main Bazar, 092721 Mustafa Shabheed, 092717 Shan Muhammad, 092703 Shan Pur, 092706 Sahail Pur, 092705 Ali Pur, 092716 Mehr Shah, 092710 Anayat Ali, 092720 Mangwani, 092704 Qadir Pur Cheema, 092713 Burhan Pur 098201, Ali Sher, 098202 Thatha Road, 098206 Sadat, 098208 Khushi Muhammad, 098209 City Noor Peer, 098210 Ghulam Rasool, 098203 Jallian, 098207 City Dunya Pur, 098204 Qutab Pur, 098205 Nasrullah Tarni, 098211 Model Town, 098212 Sadq Shabheed, THQ Dunya Pur feeders	Abdul Rahman (AEM Vahan) 0319-9765644
36	MEPCO	132KV Ludden-Karam Pur T/L controlled by 132KV CBS LDN-2 - KPU-1	20.01.26	Tuesday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Karam Pur 068507 Attab Mehrwood, 068504 Tpu, 068508 Muhammad Shan, 068502 Hassan Shah, 068510 Zia Shabheed, 068501 Karam Pur, 068503 Tabark Wahn & 068509 Idrees Shabheed feeders	Behzad Ali (AET Hasil Pur) 0319-9765642
37	MEPCO	132KV Pakpattan/ Pakpattan-Noor pur T/L controlled by 132KV CB PPT-1-NPR-3	21.01.26	Wednesday	9:00	12:00	Annual maintenance / testing of 132KV CB PPT-1 & Line Isolator No. 101	11KV O/G Power House (015406), Chak Shaif (015403), Sanday Kha (015408), Malka Hance (015405), Khawaja Aziz Malki (015411), Husain Abad (015404), Chan Peer (015415), Al-Fareed (015401), New Malka Hance (015422), Bonga Hayat (015402), Fareed Nagar (015424), Ghulam Hayder (015418), Sarwar Shabheed (015419), Mehboob Shah (015417), Jail (015416), D.H.Q (015423), Mubasher Shabheed (015425), Dost Muhammad (015427), Moji Darya (015430), Masoom Shah (015412), City (015410), Saliu (015407), Miran Shah (015409), Gunj Shakar (015413), Iqbal Shabheed (015426), Abdul Kareem (015414), Mushiq Shabheed (015428), Ali Mahi (015429) <u>(28-No feeders)</u>	Muhammad Akram FM Cell # 0302-7892530
38	MEPCO	132KV Pakpattan/ 132 Bus Bar controlled by 132KV CB's PPT-1 & PPT-2 along with transmission lines	21.01.26	Wednesday	9:00	15:00	Annual maintenance of 132KV Bus Bar, line isolator No. 101 & 102, 11KV Bus Coupler and tightening of all power cables as well as Jumpers & droppers	Muhammad Akram FM Cell # 0302-7892530 M. Nafees, LS-I Cell # 0319-9765678	

P-06

No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
39	MEPCO	132KV Hasil Pur/ 132KV Bus Bar T/L controlled by 132KV CBS HSP-1, HSP-2, HSP-3, HSP-4, HSP-7 and 66 KV CB HSP-5	21.01.26	Wednesday	9:00	15:00	Annual maintenance of 132KV bus bar	(Whole area of 132KV GIS Hasil Pur, Chuna Wala and 66KV GIS Bukhsan Khan & Chishtian) 11 KV O/G 047205 Hospital, 047208 Jinal Pur, 047206 Vehari Road, 047202 Old Hasil Pur, 047215 Saliuj, 047210 Sheikh Wahn, 047212 AL Tahir, 047201 City-I, 047203 Tidewell, 047204 M/Friah, 047209 Al Hader, 047214 Settlement Town, 047213 City-II Hasil Pur, 047211 Water Works, 047216 Inaytee, 047217 Qalandar Pur, 047218 Shah Pur, 047219 Islam Pura, 047220 Sarwar Kol, 077301 City Chuna Wala, 077302 New Cholistan and 077303 Al-Fateh, 025302 Madrassa, 025307 Main Bazar, 025306 Park, 025308 Gulshan, 115101 City-I Bukhsan Khan, 115103 Syadan Wala & 115102 City-II Bukhsan Khan	Abdul Rahman (AEM Vehari) 0319-9765644
40	MEPCO	132KV Bahawal Nagar II-Minchin Abad T/L controlled by 132KV CB BNR-2 - MNA-1	21.01.26	Wednesday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV GIS Minchin Abad & Meleod Gunj 054504 Fidal Shah, 054502 City Minchin Abad, 054505 Railway Road, 054506 Farooq Shahneed, 054503 Merimood, 054501 PPN Road, 032705 M/Gunj, 054507 M.S.G Road, 032704 M Abad-II, 032706 Anwar Shahneed, 032707 Al-Mushaq, 032702 City, 032701 Annuka, 032703 M/Abad/I & 032708 Head Sulemanki feeders	Behzad Ali (AET Bahawal Nagar) 0319-9765643
41	MEPCO	132KV/Hoota/ 132KV Bus Bar controlled by 132KV CBs HOT-1 HOT-2 along with transmission lines	22.01.26	Thursday	9:00	16:00	Annual maintenance of 132KV Bus Bar and line isolator No. 101, 102 alongwith 11KV Bus Coupler & Tightening of 11KV cables	11KV O/G Dewan Distheer (077503), Hoota City (077502), Baba Moshan Shah (077504), Kot Bakhsia (077508), Baba Khaki Shah (077509), Irshad Disigneer (077505), Zafar shahneed (077507) & Baba Fareed (077506), Kala Pathan (NA) (09-No feeders)	Muhammad Akram FM Cell # 0319-9765770 M. Nafees, LS-I Cell # 0319-9765678

P=07

No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
42	MEPCO	132KV Sahuka-Burewala old T/L controlled by 132KV CB SKA-1-BWO-2	22.01.26	Thursday	9.00	14.00	Washing / cleaning of disc insulators	11KV O/G Sadat (053709), Umar Pu (053703), Al-Abbas (053705), Murad Ali (053707), Jamliya (053706), Sahuka (053702), Saldara (053704), Samar Shah (053708), Hajji Sher (053701), Jodhaka (053710), Subhan Shah (053711) & Yousaf Shabeed (12-No feeders)	Altar Hussain, LS-1 Cell # 0319-9765744
43	MEPCO	132KV Haroon Abad/ 132KV bus bar controlled by 132KV CBs HRB-1, HRB-2, HRB-3, HRB-4 & HRB-5	22.01.26	Thursday	9:00	15:00	Annual Maintenance of 132KV bus bar	Whole area of 132KV GIS Haroon Abad, Donga Bonga, Faqir Wail, Knichi Wala, Fort Abbas and Marol. 11 KV O/G 092412 Gulab Ali, 092408 Banglow Road, 092401 City-I, 092414 Mubank Abad, 092413 Dahran Wala Road, 092415 Canal City, 092402 Muslim City, 092404 City-2, 092407 Mian Wala Banglow, 092416 THQ Hospital, 092417 Grain Market, 092410 Model Avenue, 092406 Pui Murad, 092403 Donga Bonga, 092405 Khataan, 092418 Eastern Products VIT AL Pvt Ltd, 054101 City Faqir Wail, 054103 Wains, 054106 Canal TR, 054107 City-II Faqir Wail, 054102 Yateen Wala, 054104 Rural, 054105 Mehna City, 054108 Siddhu, 027601 City Fort Abbas, 027605 Fort, 027602 Quirash, 027607 Raing Shabeed, 027603 Knichi Wala, 027604 Walhar, 027606 Rafique Abad, 027608 THQ Hospital Fort Abbas, 120803 Salfar Shabeed, 120805 City Knichi Wala, 120802 75 Adda, 120801 Fazal Shah, 120804 Latif Abad, 060601 Marol-I, 060602 City Marol, 060603 Mansoor, 060604 Cholistan, 060605 Zia, 060606 Rohi, 060607 Sarder, 060608 Chappu & 060609 Meer Gath 130302 City Donga Bonga, 130301 Rasool Pura, 130304 Muhib Ali, 130303 Chishti feeders	Abdul Rahman (AEM Verhan) 0319-9765644

P=08

No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
44	MEPCO	132KV Vehari/ 132KV bus bar controlled by 132KV CBs VRI-1, VRI-2, VRI-3, VRI-4 & VRI-5	24.01.26	Saturday	9:00	15:00	Annual Maintenance of 132KV bus bar	Whole area of 132KV G/S Vehari 11 KV O/G 021921 DHQ Hospital, 021906 Noor Shah, 021913 Ratta Tibba, 021916 Machiwai, 021917 Dana Ibrahim, 021915 SS Oil Mills, 021919 District Jail Vehari, 021908 Bilal, 021928 Industrial Estate & 021929 Pakhi More, 021910 Water Works, 021911 City-1, 021905 MES Thingi, 021922 Liaqat Shahed, 021920 TRW Vehari, 021912 City-2, 021909 T/Shahed, 021903 Chak 37W/B, 021927 Club Road, 021902 Chak 22W/B, 021901 Creacent Factory, 021918 Chak 182/E.B, 021923 Defence View, 021924 SS Feeds, 021925 City-III, 021930 Defence View VIP Block, 021928 Madina Colony, 021914 New Chak 37 W/B feeders	Abdul Rahman (AEM Vehari) 0319-9765644
45	MEPCO	132KV Kassowal New/ 132KV Bus Bar controlled by 132KV CB KSW-1 - KSW-2 along with T/Lines	26.01.26	Monday	9:00	15:00	Annual maintenance of 132KV Bus Bar and line isolator No. 101 & 102 along with 11KV Bus Coupler and tightening of 11KV power cables	11KV O/G Dargas Colony (120301), Baba Khaki Shah (120302), Chak 50 (120303), Chak 6 (120305), Muneer Abad (120304) [05-No feeders]	Muhammad Akram FM Cell # 0319-9765770 Altair Hussain, LS-I Cell # 0319-9765744
46	MEPCO	132KV Noor Ser/ 132/11KV 10/13 MVA P/TF T-2	26.01.26	Monday	9:00	15:00	Annual Maintenance/testing	(11 KV O/G 054602 Takht Mahal and 054603 Land Wala feeders)	Abdul Rahman (AEM Vehari) 0319-9765644
47	MEPCO	132KV Kehror Pacca-Dunya Pur T/L controlled by 132KV CB KRP-1 & 101	26.01.26	Monday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Dunya Pur 098201 Ali Sher, 098202 Thatha Road, 098206 Sadat, 098208 Khushi Muhammad, 098209 City Noor Peer, 098210 Ghulam Rasool, 098203 Jalil, 098207 City Dunya Pur, 098204 Quah Pur, 098205 Nasrullah Tarni, 098211 Model Town & 098212 Sadiq Shahed, THQ Dunya Pur feeders	Obaid Ullah (AET Vehari) 0319-9765641

8-09/26

No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
48	MEPCO	132KV Hasil Pur-Chuna Wala T/L controlled by 132KV CB HSP-7, CNW-1	26.01.26	Monday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Chuna Wala 077301 City Chuna Wala, 077302 New Cholaistan and 077303 AL-Faten feeders	Behzad Ali (AET Hasil Pur) 0319-9765642
49	MEPCO	132KV Chichawathi/ 132KV Bus Bar No-1 & 2, controlled by 132KV CB's CCW-1, CCW-2, CCW-3, CCW-4, CCW-5, CCW-6 & CCW-7 along with transmission lines	27.01.26	Wednesday	9:00	16:00	Annual maintenance of 132KV Bus Bar No-1 & 2 & Line Isolator No. 101, 102, 103, 104, 105, 106 & 107, 11KV Bus Coupler & Tightening of 11KV power cables	11KV O/G Sher Wala (002709), Ghazi Abad (002711), Harappa (002706), Kot Muhammad (002716), Choudary Feed Mills (002717), Dad Fallana (002719), Al-Noor (002720) & Kassowal (002708) 11KV O/G Chichawathi Old (002702), Adeeb Shahed (002701), City (002703), Firdous (002704), Hazoor Abad (002710), Raj Kot (002721), Muhammad Abad (002715), T.H.Q Chichawathi (002718) & Imtiaz Textile Mill (002714), 11KV O/G Sheikh Tayyab (002713), New City (002712), Industrial (002707) <u>[20-No Feeders]</u>	Muhammad Akram FM Cell # 0319-9765770 M. Nafees, LS-I Cell # 0319-9765678 Aliaf Hussain, LS-I Cell # 0319-9765744
50	MEPCO	132KV Ludden/ 132KV Bus Bar controlled by 132KV CB LDN-1, 101, LDN-2, 102, LDN-3, 103 & LDN-4, 104	27.01.26	Tuesday	9:00	15:00	Annual maintenance of 132KV bus bar	Whole area of 132KV G/S Ludden & Karam Pur 031703 Ludden, 031702 Firdous, 031706 Sajwar Shahed, 031707 Farooq Shahed, 031701 Ahmad Abad, 031704 Dolek Abad, 031705 Nadir Waji, 031708 Shams Abad, 031709 Head Islam, 068507 Atab Mehmood, 068504 Tipu, 068508 Muhammad Shah, 068502 Hassan Shah, 068510 Zia Shahed, 068501 Karam Pur, 068503 Tabark Waji & 068509 Idrees Shahed feeders	Abdul Rahman (AEM Vihar) 0319-9765644

P=10 fm

No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
51	MEPCO	132KV Ludden-Karam Pur T/L controlled by 132KV CBS LDN-2-KPU-1	27.01.26	Tuesday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Karam Pur 068507 Atiab Mehmood, 068504 T/pu, 068508 Muhammad Shah, 068502 Hassan Shah, 068510 Zia Shahneed, 068501 Karam Pur, 068503 Tabark W/ah & 068509 Idrees Shahneed feeders	Behzad Ali (AET Hasil Pur) 0319-9765642
52	MEPCO	132KV Bahawal Nagar II-Minchin Abad T/L controlled by 132KV CB BNR-2 - MNA-1	27.01.26	Tuesday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Minchin Abad & Meekood Guni 054504 Fidal Shah, 054502 City Minchin Abad, 054505 Railway Road, 054506 Farooq Shahneed, 054503 Mehmood, 054501 PPN Road, 032705 M/Guni, 054507 M.S.G Road, 032704 M.Abad-II, 032706 Anwar Shahneed, 032707 Al-Mushlaq, 032702 City, 032701 Annaka, 032703 W/Abad/I & 032708 Head Sulemanik feeders	Behzad Ali (AET Bahawal Nagar) 0319-9765643
53	MEPCO	132KV Bunga Hayat/ 132KV Bus bar controlled by 132KV CB BGH-1, BGH-2 alongwith T/Lines	28.01.26	Wednesday	9:00	16:00	Annual maintenance of 132KV Bus Bar and line isolator No. 101 & 102 and 11KV Bus Coupler & tightening of 11KV power cables	11KV O/G Sharafat Pura (001707), Ghazi Mardan (001703), Army Farm (001705), Doctor Adnan Shahneed (001711), Ronak Shahneed (001710), Chak 67/D (001712), 11KV O/G Chak Bad (001701), Qudrat Ullah (001702), Sikandar Chowk (001706), Zubair Feed (01708), Farid Kot (001709), Al-Vardi (001704), Wandela Jangeer (001713) [13.No Feeders]	Muhammad Akram FM Cell # 0319-9765770 M. Nafees, LS-I Cell # 0319-9765678

P-11

Sl. No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
54	MEPCO	132KV Chishtian/ 132KV bus bar controlled by 132KV CB CNN-1, CNN-2, CNN-3, CNN-4	28.01.26	Wednesday	9:00	15:00	Annual maintenance of 132KV bus bar	Whole area of 132KV G/S Chishtian 11 KV O/G 072808 City-2nd, 072801 College, 072803 Manghar Sharf, 072811 Eid Gah Road and 072815 Munee Sharheed, 072807 City-1st, 072812 Azeem Wah, 072813 THQ Hospital, 072814 3 Maria Housing Scheme, 072816 Sailu, 072817 Fareed Kot, 072802 Mohar Sharf, Gul Shah, 072810 Seelie Town, 072804 Shouze Elahi, 072806 Sher Fareed, 072809 Gafan, 072805 Gajiani feeders	Abdul Rahman (AEM Vehari) 0319-9765644
55	MEPCO	132KV Qadir Abad/ 132KV Bus Bar controlling 132KV CB's QDR 1, QDR-2, QDR-3, QDR-4, QDR-5 & QDR-6 alongwith T/Lines	29.01.26	Thursday	9:00	15:00	Annual maintenance of 132KV Bus Bar, line Isolator No. 101, 102, 103, 104, 105 & 106 11KV Bus Coupler and tightening of all power cables as well as Jumpers & droppers	11KV O/G Hafiz Daim (016602), Chak 734-R (016610), Asia Poultry Feeds (016607), Qadir Abad (016604), Chak 46/5-L (016609), Khan Kamal (016603), Nargis Textile Mills (016605) (MEPCO), 11KV O/G Gamber (016601), Lakson Tobacco Co (016609) (LESCO) Whole area of 132KV Sadar Gogera (LESCO) 09-No Feeders effected	Muhammad Akram FM Cell # 0302-7892530 M. Nafees, LS-I Cell # 0319-9765678
56	MEPCO	132KV Qadirabad/ 132KV Qadirabad-Sadar Gogera (LESCO) T/L controlled by 132KV CB QDR-2 & 101	29.01.26	Thursday	9:00	12:00	Annual maintenance / testing of 132KV CB QDR-2 & Line Isolator No. 102	Whole area of 132KV G/S Sadar Gogera (LESCO)	Muhammad Akram FM Cell # 0302-7892530
57	MEPCO	132KV Garha More/ 132KV bus bar controlled by 132KV CBs GRM-1 - GRM-2	29.01.26	Thursday	9:00	15:00	Annual Maintenance of 132KV bus bar	Whole area of 132KV G/S Garha More 11 KV O/G 004202 Mitru, 004209 Dillu More, 004204 Chak Shahana, 004207 Basheer Sharheed, 004210 Khalid Bin Waleed, 004201 Garha More, 004205 Sher Shah, 004203 Ghulam Hussain, 004208 Chaklari, 004206 Shlab Garh feeders	Abdul Rahman (AEM Vehari) 0319-9765644

F-12

No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
58	MEPCO	66KV Hasil Pur-Chishtian T/L controlled by 66KV CB HSP-5 - CHN-1	29.01.26	Thursday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 66KV Grid Station Bukhsan Khan and Chishtian 025302 Madrassa, 025307 Main Bazar, 025306 Park, 025308 Gulshan, 115101 City-I Bukhsan Khan, 115103 Syadan Wala & 115102 City-II Bukhsan Khan	Behzad Ali (AET Hasil Pur) 0319-9765642
59	MEPCO	132KV Fort Abbas-Marrot T/L controlled by 132KV CB FTA-2 - MRT-2	29.01.26	Thursday	9:00	15:00	Washing/cleaning of disc insulators	Whole area of 132KV G/S Marrot. 060601 Marrot-I, 060602 City Marrot, 060603 Mansoor, 060604 Chishtian, 060605 Zia, 060606 Rch, 060607 Sardar, 060608 Chappu & 060609 Meer Gann feeders	Behzad Ali (AET Bahawal Nagar) 0319-9765643
P-13									