

Tel : 061-6305545

Fax: 061-6305546

No. : 10783-94 /

Office of

The Chief Executive

Dated: 16/01/2026.

Superintending Engr: (GSO) MEPCO Circle Sahiwal.

Subject: APPROVAL OF SHUT DOWN.

Ref. SE GSO MEPCO Circle Sahiwal letter No. 383-90 dated 15.01.2026.

The shut down as required by you is hereby approved subject to publication in the important news add papers as well as prior information to all important / dedicated consumers duly confirmed in writing and their concurrence. In addition the announcement through loudspeakers of Mosques be made for the information of General Public. It is also requested to direct SSO Incharge of concerned Grid Station to implement the revised load shedding schedule strictly as directed by worthy GM (Op) MEPCO HQ Multan.

Sr No	Disco	Name of Grid Station / Name of Equipment	Date & Time	Purpose Of Shutdown	Effected Area
1	MEPCO	132KV Faqir wali/ 132KV Faqir wali - Fort Abbas T/L, Controlling 132KV CB FQW-4 - FTA-1	24.01.2026 To 25.01.2026 08:00 To 18:00 (10 Hrs Daily)	Erection of ZM-30 & ZM-60 type towers under the line and allied stringing work	<u>Whole area of 132KV G/S Fort Abbas and Marrot</u> 027601 City Fort Abbas, 027605 Fort, 027602 Quraish, 027607 Rafiq Shaheed, 027603 Khichi Wala, 027604 Walhar, 027606 Rafique Abad, 027608 THQ Hospital Fort Abbas, 060601 Marrot-1, 060603 Mansoora, 060604 Cholistan, 060605 Zia, 060606 Rohi, 060607 Sardar, 060608 Chappu & 060609 Meer Garh feeders
2		132KV Faqir wali/ 132KV Faqir wali - Fort Abbas T/L, Controlling 132KV CB FQW-4 - FTA-1	27.01.2026 To 28.01.2026 08:00 To 16:00 (08 Hrs Daily)	Stringing of 132KV Khichi Wala-Fort Abbas T/Line at tower No. 119 to 120. alongwith interfacing of the revised arrangement and dismantling of existing tower No. 119	
3		132KV Faqir wali/ 132KV Faqir wali - Fort Abbas T/L & 132KV Fort Abbas Bus Bar Controlled by 132KV CB FQW-4 - FTA-1 & FTA-2	31.01.2026 08:00 To 16:00 (08 Hrs Daily)	Provision of dropper for bus and line isolator and energization of newly constructed line bay at 132KV G/S Fort Abbas	

NOTE: Shahbaz Ali LS-II No.0307-7709732 has been declared as Safety Supervisor for this Shutdown as told by XEN T&G "C" Divn GSC MEPCO.


It must be ensured that the timings of the shutdown are observed strictly & the electricity supply is restored accordingly.

This issues with the approval of Chief Engineer (O&M) Distrn: MEPCO Multan.

Note:- The compensation schedule must be implemented in true spirit as per directions of worthy Chief Engineer (Op) MEPCO HQ Multan.

DA/Schedule of shut down.

C.C.


Dy: Manager (O&M) Distrn:
MEPCO Ltd. Multan

- 1- General Manager (Op) MEPCO HQ Multan for information along with Compensation schedule in load shedding programme please.
- 2- Chief Engineer (O&M) Distrn: for information as desired please.
- 3- CE NPCC Islamabad / Director RCC Jamshoro for information please.
- 4- S.E. (OP) MEPCO B/Nagar w.r. to his letter No.1195-1203 dated 15.01.2026 with Compensation schedule in load shedding programme as received from your office with the request to implement the schedule.
- 5- Director (IT) MEPCO Multan for necessary action & uploading on website, please.
- 6- XEN (Op) MEPCO Haroon abad Div with the advise to carry out Maintenance works on the said feeders during this approved shut down as desired by Competent Authority.
- 7- Dy: Manager M.P.C.C MEPCO Multan along with Compensation schedule in load shedding programme for Implementation & also to inform PITC & load on Roshan Pakistan app. pl.
- 8- Dy: Manager R.C Cell for information and necessary action.
- 9- Addl: Manager (P.R) MEPCO H/Q Multan with the advice to arrange Publication in newspapers & announcement through Electronic media & send the press cutting of above shut down.
- 10- Mr.Ameer Hamza SSO-I/ Safety Inspector (HSE) with the directions to monitor the above shut down and ensure the implementation of all Safety measures in true letter & Spirit as per MEPCO SOP.