

Tel : 061-6305545

Fax: 061-6305546

No. : 11882-921

Office of

The Chief Executive

Dated: 02/02/2026.

Superintending Engr: (GSO) MEPCO Circle Sahiwal.

Subject: APPROVAL OF SHUT DOWN.

Ref. SE GSO MEPCO Circle Sahiwal letter No. 718-25 dated 29.01.2026.

The shut down as required by you is hereby approved subject to publication in the important news add papers as well as prior information to all important / dedicated consumers duly confirmed in writing and their concurrence. In addition the announcement through loudspeakers of Mosques be made for the information of General Public. *It is also requested to direct SSO Incharge of concerned Grid Station to implement the revised load shedding schedule strictly as directed by worthy GM (Op) MEPCO HQ Multan.*

Sr No	Disco	Name of Grid Station / Name of Equipment	Date & Time	Purpose Of Shutdown	Effected Area
1	MEPCO	132KV Faqir wali/ 132KV Faqir wali - Fort Abbas T/L, Controlling 132KV CB FQW-4 - FTA-1	09.02.2026 To 10.02.2026 08:00 To 18:00 (10 Hrs Daily)	Erection of ZM-30 & ZM-60 type towers under the line and allied stringing work	<u>Whole area of 132KV G/S Fort Abbas and Marrot</u> 027601 City Fort Abbas, 027602 Quraish, 027607 Rafiq Shaheed, 027603 Khichi Wala, 027604 Walhar, 027606 Rafique Abad, 027608 THQ Hospital Fort Abbas, 060601 Marrot-1, 060603 Mansoora, 060604 Cholistan, 060605 Zia, 060606 Rohi, 060607 Sardar, 060608 Chappu & 060609 Meer Garh feeders
2		132KV Faqir wali/ 132KV Faqir wali - Fort Abbas T/L, Controlling 132KV CB FQW-4 - FTA-1	11.02.2026 To 12.02.2026 08:00 To 16:00 (08 Hrs Daily)	Stringing of 132KV Khichi Wala-Fort Abbas T/Line at tower No. 119 to 120. alongwith interfacing of the revised arrangement and dismantling of existing tower No. 119	
3		132KV Faqir wali/ 132KV Faqir wali - Fort Abbas T/L & 132KV Fort Abbas Bus Bar Controlled by 132KV CB FQW-4 - FTA-1 & FTA-2	16.02.2026 To 17.02.2026 08:00 To 16:00 (08 Hrs Daily)	Provision of dropper for bus and line isolator and energization of newly constructed line bay at 132KV G/S Fort Abbas	

NOTE: Shahbaz Ali LS-II No.0307-7709732 has been declared as Safety Supervisor for this Shutdown as told by XEN T&G "C" Divn GSC MEPCO.

It must be ensured that the timings of the shutdown are observed strictly & the electricity supply is restored accordingly.

This issues with the approval of Chief Engineer (O&M) Distn: MEPCO Multan.

Note:- The compensation schedule must be implemented in true spirit as per directions of worthy Chief Engineer (Op) MEPCO HQ Multan.

DA/Schedule of shut down.

C.C.

21/02/2026
Dy: Manager (O&M) Distn:
MEPCO Ltd. Multan

- 1- General Manager (Op) MEPCO HQ Multan for information along with Compensation schedule in load shedding programme please.
- 2- Chief Engineer (O&M) Distn: for information as desired please.
- 3- CE NPCC Islamabad / Director RCC Jamshoro for information please.
- 4- S.E. (OP) MEPCO B/Nagar w.r. to his letter No. 2091-99 dated 29.01.2026 with Compensation schedule in load shedding programme as received from your office with the request to implement the schedule.
- 5- Director (IT) MEPCO Multan for necessary action & uploading on website, please.
- 6- XEN (Op) MEPCO Haroon abad Div with the advise to carry out Maintenance works on the said feeders during this approved shut down as desired by Competent Authority.
- 7- Dy: Manager M.P.C.C MEPCO Multan along with Compensation schedule in load shedding programme for Implementation & also to inform PITC & load on Roshan Pakistan app. pl.
- 8- Dy: Manager R.C Cell for information and necessary action.
- 9- Addl: Manager (P.R) MEPCO H/Q Multan with the advice to arrange Publication in newspapers & announcement through Electronic media & send the press cutting of above shut down.
- 10- Mr. Ameer Hamza SSO-I/ Safety Inspector (HSE) with the directions to monitor the above shut down and ensure the implementation of all Safety measures in true letter & Spirit as per MEPCO SOP.