

Tel : 061-6305545
Fax: 061-6305546
No. : 17554-651

Office of
The Chief Executive
Dated: 06/05/2026

**Superintending Engr: (GSO)
MEPCO Circle Multan.**

Subject: **APPROVAL OF SHUT DOWN.**

Ref. SE GSO MEPCO Circle Multan letter No. 4559-74 dated 30.04.2026.

The enclosed shut downs as required by you is hereby approved subject to publication in the important newspapers as well as prior information to all important / dedicated consumers duly confirmed in writing and their concurrence. In addition the announcement through loudspeakers of Mosques be made for the information of General Public. *It is also requested to direct SSO Incharge of concerned Grid Station to implement the revised load shedding schedule strictly as directed by worthy GM (Op) MEPCO HQ Multan.*

NOTE: All Safety Supervisor Names and Nos enclosed / Atteched all Copies of this shut downs as told by SE GSO Multan.

It must be ensured that the timings of the shutdown are observed strictly & the electricity supply be restored accordingly.

This issue with the approval of Chief Engineer (O&M) Distn. MEPCO Multan.

Note:- The compensation schedule must be implemented in true spirit as per directions of worthy Chief Engineer (Op) MEPCO HQ Multan.

DA/Schedule of shut down.

P=01 TO 06

C.C.

WZZZZZZ
**Dy: Manager (O&M) Distn:
MEPCO Ltd. Multan**

- 1- General Manager (Op) MEPCO HQ Multan for information along with Compensation schedule in load shedding programme please.
- 2- Chief Engineer (O&M) Distn: for information as desired please.
- 3- CE NPCC Islamabad / Director RCC Jamshoro for information please.
- 4- S.E. (OP) MEPCO MEPCO RY Khan ,M.Garh & DG Khan w.r. to their letter No. 8787-93 dated 04.05.2026, No. 9006-10 Dated 30.04.2026 & 26207-16 Dated 05.05.2026 with Compensation schedule in Load shedding programme as received from your office with the request to implement the schedule.
- 5- Director (IT) MEPCO Multan for necessary action & uploading on website, please.
- 6- Dy.Manager (O&M) T&G for information as desired please.
- 7- All XENS under (Op) Circles RY Khan,M.Garh & DG Kgan MEPCO Div with the advise to carry out Maintenance works on the said feeders during this approved shut down as desired by Competent Authority.
- 8- Dy: Manager M.P.C.C MEPCO Multan along with Compensation schedule in load shedding programme for Implementation & also to inform PITC & load on Roshan Pakistan app. pl.
- 9- Dy: Manager R.C Cell for information and necessary action.
- 10- Addl: Manager (P.R) MEPCO H/Q Multan with the advice to arrange Publication in newspapers & announcement through Electronic media & send the press cutting of above shut down.
- 11- Mr.Ameer Hamza SSO-I/ Safety Inspector (HSE) with the directions to monitor the above shut down and ensure the Implementantion of all Safety measures in true letter & Spirit as per MEPCO SOP.

**SHUT DOWNS OF GRID STATION'S EQUIPMENT
I.R.O GSO CIRCLE MEPCO MULTAN FOR 05/2026 (Area Affect)**


Sr. No.	Disco	Name of Grid Station / Transmission Line & Name of Equipment	Date	Time		Purpose of Shut Down	Affected Area	Safety Inspector
				From	To			
1	MEPCO	132KV Layyah / T-3, 132/11.5KV, 26MVA PTF	Monday, 04.05.26	08:30	10:30	For safety purpose due to maintenance of bus coupler	Power House-I (031603), Sugar Mill (031604), Sh: Jalal-ud-Din (031615), Shah Habib (031614) & Koda Haji Shah (031616)	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
2	MEPCO	132KV Layyah / T-2, 132/11.5KV, 26MVA PTF	Monday, 04.05.26	08:30	14:30	For six monthly maintenance.	Eid Gah (031609), City-III (031611), DHQ (031613) & Fateh Sher (031617)	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
3	MEPCO	132KV Layyah / T-3, 132/11.5KV, 26MVA PTF	Tuesday, 05.05.26	08:30	14:30	For six monthly maintenance.	Power House-I (031603), Sugar Mill (031604), Sh: Jalal-ud-Din (031615), Shah Habib (031614) & Koda Haji Shah (031616)	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
4	MEPCO	132KV Fort Manru / (P/Tr. T-1, 10/13 MVA)	05.05.2026 (Tuesday)	09:30	15:30	For Six Monthly Maintenance	Fort Munro (070501), Bawata-II (070502), Bawata-II (070503), Anant (070504), THQ Level Hospital (070505), Power House-2 (031607), City-2 (031606), District Jail (031612) & Mushaq Abad (031610)	Mr. Zafar Iqbal (FM) 0319-9765543
5	MEPCO	132KV Layyah / T-4, 132/11KV, 26MVA PTF	Wednesday, 06.05.26	08:30	14:30	For six monthly maintenance.	017108-Bahadur Pur, 017111-Palace, 017129-ATM-4, 017110-Circular, 017133-Pahq Abad, 017120-ATM-II, 017134-Factory Area, 017132-Hussain Abad, 017135-Muslim, 017136-Rehman Colony, S.S.Din (54701), Bahadur Garh (54704), Dari Dholay Wali (54705)	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
6	MEPCO	132KV Grid Station Rahim Yar Khan-I T-3 (31.5/40MVA)	06.05.2026	8:00	14:00	Six Monthly Maintenance		Mr. Akhlaq (Foreman) 0301-7643310
7	MEPCO	132KV Shah Sadar Dhn / (P/Tr. T-2, 20/26 MVA)	06.05.2026 (Wednesday)	07:30	13:30	For Six Monthly Maintenance		Mr. Zafar Iqbal (FM) 0319-9765543
8	MEPCO	132KV Gujrat / T-2, 132/11KV, 20/26MVA PTF	Thursday, 07.05.26	08:30	10:30	For safety purpose due to maintenance of bus coupler	Ghazi Ghat (005203), Sharif Ansari (005213), Mahmood Kot (005201), FSM (005209), Gurmani (005205) & Al-Faisal (005214)	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
9	MEPCO	132KV Gujrat / T-1, 132/11KV, 20/26MVA PTF	Thursday, 07.05.26	08:30	14:30	For six monthly maintenance.	Baseera (005211), Noor Kubra (005216), Gujrat (005204), Dibbi Shah (005212) & PSO (005208)	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
10	MEPCO	132KV Grid Station Rahim Yar Khan-II T-3 (31.5/40MVA)	07.05.2026	8:00	14:00	Six Monthly Maintenance	076704-Shah Garh, 076714-Sultan Pur, 076716-New Satellite Town, 076717-Rohi, 076718-Model Town, 076719-District Jail, 076720-Villas, 076721-Ab-e-Hayat, 076715-Medical College, 076723-Ravi, 076724-Bari, 076725-Ethhad Garden-1, 076726-Ethhad Garden-2, 076727-Zaman Shahneed, 076728-Sadiq Canal	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.

P-01/lu

M. Akhlaq (Foreman)
0301-7643310

Sl. No.	Disco	Name of Grid Station / Transmission Lines & Name of Equipment	Date	Time		Purpose of Shut Down	Affected Area	Safety Inspector
				From	To			
11	MEPCO	132KV DG Khan-1 / (P/Tr. T-2, 31.5/40 MVA)	07.05.2026 (Thursday)	07:30	13:30	For Six Monthly Maintenance	College Road-I (3310), Paigah (3312), Khayaban-e-sarwar (3314), DHQ-I (3320), Malian Road (3328), Jampur Road (3330)	Mr. Zafar Iqbal (FM) 0319-9765543
12	MEPCO	132KV DG Khan-1 / (P/Tr. T-1, 31.5/40 MVA)	07.05.2026 (Thursday)	07:30	09:30	For Safety Purpose Due to Bus Coupler Maintenance	CTM (3301), Industrial (3302), Quetta Road (3304), Gaddai-I (3306), Chit Sirkan (3321), Wadoor (3322), Water supply (3324), Danish School (3325), Express (3326), New Defence Housing Scheme (3327), NDVHS Commercial (3331), Darri Meero (3332), P.G.S.H.S. (3333) D.G.H.S (3334)	Mr. Zafar Iqbal (FM) 0319-9765543
13	MEPCO	132KV Gujrat / T-2, 132/11KV, 20/26MVA PTF	Saturday, 09.05.26	08:30	14:30	For six monthly maintenance.	Ghazi Chat (005203), Sharif Ansari (005213), Mahmood Kot (005201), FSM (005209), Gurmani (005205) & Al-Faisal (005214)	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
14	MEPCO	132KV Grid Station Sadig Abad T-3 (31.5/40MVA)	10.05.2026	8:00	14:00	Six Monthly Maintenance	018129-Johar Town, 018113-Express-2, 018105-old manthar, 018120-Model town, 018119-Jinnah Town, 018122-ALFM, 018109-Feeder No.4	M. Akhlaq (Foreman) 0301-7643310
15	MEPCO	132KV DG Khan-1 / (P/Tr. T-3, 31.5/40 MVA)	10.05.2026 (Sunday)	07:30	13:30	For Six Monthly Maintenance	Civil line-I (3315), Samina (3317), Chabri Bala (3318), Sarwar Wall (3319), College road-II (3323), Naurang Abad (3329)	Mr. Zafar Iqbal (FM) 0319-9765543
16	MEPCO	132KV Chowk Azam / T-2, 132/11KV, 40MVA PTF	Monday, 11.05.26	08:30	10:30	For safety purpose due to maintenance of bus coupler	Ladhana (073003), City-I (073001), City-II (073004), Rafiq Abad (073006), Dhori (073005) & Darbar Kamal Chishti (073009)	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
17	MEPCO	132KV Chowk Azam / T-1, 132/11KV, 13MVA PTF	Monday, 11.05.26	08:30	14:30	For six monthly maintenance.	Lalazar (073002), MGC (073007) & THQ (073008)	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
18	MEPCO	132KV Grid Station Sadig Abad T-1 (31.5/40MVA)	11.05.2026	8:00	14:00	Six Monthly Maintenance	018118-Musa Nagar, 018126-Crown Motors, 018101-Bhong, 018106-Sanjhar Pur, 018124-New Satellite Town, 018112-Express-1, 018123-Model City, 018107-Nawaz Abad, 018130-Shan Floor Mill, 018131-Ajmal Bagh, 018132-Nawab Sadig, 018133-Model Avenue, 018134-Ahmad Pur Lamma, 018135-Industrial State-2, 018137-Chaman, 018139-Noor Wala, 018138-Adam Sahaba, 018127-Industrial Estate-1, 018140-Unique City, 018136-Kander, 018141-Roshan Bhat.	M. Akhlaq (Foreman) 0301-7643310
19	MEPCO	132KV Rojhan / (P/Tr. T-1, 10/13 MVA)	11.05.2026 (Monday)	09:30	14:30	For Six Monthly Maintenance	018118-Musa Nagar, 018126-Crown Motors, 018101-Bhong, 018106-Sanjhar Pur, 018124-New Satellite Town, 018112-Express-1, 018123-Model City, 018107-Nawaz Abad, 018130-Shan Floor Mill, 018131-Ajmal Bagh, 018132-Nawab Sadig, 018133-Model Avenue, 018134-Ahmad Pur Lamma, 018135-Industrial State-2, 018137-Chaman, 018139-Noor Wala, 018138-Adam Sahaba, 018127-Industrial Estate-1, 018140-Unique City, 018136-Kander, 018141-Roshan Bhat.	Mr. Zafar Iqbal (FM) 0319-9765543
20	MEPCO	132KV Rojhan / (P/Tr. T-2, 10/13 MVA)	11.05.2026 (Monday)	12:30	17:30	For Bus Coupler and Six Monthly Maintenance	Dilber (58902), Miran pur (58904)	Mr. Zafar Iqbal (FM) 0319-9765543
21	MEPCO	132KV Chowk Azam / T-2, 132/11KV, 40MVA PTF	Tuesday, 12.05.26	08:30	14:30	For six monthly maintenance.	Ladhana (073003), City-I (073001), City-II (073004), Rafiq Abad (073006), Dhori (073005) & Darbar Kamal Chishti (073009)	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
22	MEPCO	132KV Grid Station Sadig Abad T-2 (31.5/40MVA)	12.05.2026	8:00	14:00	Six Monthly Maintenance	018108-Machi Goth, 018128-Nishar, 018103-Old Satellite Town, 018117-New Manthar, 018102-City, 018111-Azad Nursery, 018125-Khawaja Fareed, 018121-Meray Shah,	M. Akhlaq (Foreman) 0301-7643310

Sl. No.	Date	Name of Grid Station / Transmission Lines & Name of Equipment	Date	Time		Purpose of Shut Down	Expected Area	Safety Inspector
				From	To			
23	MEPCO	132KV Rajanpur / (P/Tr-T-1,20/26 MVA)	12.05.2026 (Tuesday)	07:30	12:30	For Six Monthly Maintenance	City Rajanpur (35401), Kot mithon (35402), Bait Sountra (35412), Eid Gah Road (35414)	Mr. Zafar Iqbal (FM) 0319-9765543
24	MEPCO	132KV Rajanpur / (P/Tr-T-3, 10/13 MVA)	12.05.2026 (Tuesday)	12:30	16:30	For Six Monthly Maintenance	Indus Sugar Mill (35410), City Kot mithon (35411), DHQ (35415), PAF (35408) District Jail (35413), Murghai (35403)	Mr. Zafar Iqbal (FM) 0319-9765543
25	MEPCO	132KV Dammam Wala / T-2, 132/11KV, 20/26MVA PTF	Wednesday, 13.05.26	08:30	10:30	For safety purpose due to bus coupler	Kalar Wali (003601), Shehr Sultan (003602), Kotla (003607), Faiz Pur (003610), Bukhari (003609) & Bakaini (003605)	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
26	MEPCO	132KV Dammam Wala / T-1, 132/11KV, 10MVA PTF	Wednesday, 13.05.26	08:30	14:30	For six monthly maintenance.	Kandh Sharif (003603), Bat Hazari (003604) & Masoo Shah (003608)	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
27	MEPCO	132KV Rajanpur (P/Tr-T-2, 20/26 MVA)	13.05.2026 (Wednesday)	07:30	13:30	For Six Monthly Maintenance	Railway Station (35404), Shikar Pur (35409), Khawja Fareed (35416), Kotla Essan (35417)	Mr. Zafar Iqbal (FM) 0319-9765543
28	MEPCO	132KV Rajanpur / (P/Tr-T-1, 20/26 MVA)	13.05.2026 (Wednesday)	07:30	09:30	For Safety Purpose Due to Bus Coupler Maintenance	City Rajanpur (35401), Kot mithon (35402), Bait Sountra (35412), Eid Gah Road (35414)	Mr. Zafar Iqbal (FM) 0319-9765543
29	MEPCO	132KV Dammam Wala / T-2, 132/11KV, 20/26MVA PTF	Thursday, 14.05.26	08:30	14:30	For six monthly maintenance.	Kalar Wali (003601), Shehr Sultan (003602), Kotla (003607), Faiz Pur (003610), Bukhari (003609) & Bakaini (003605)	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
30	MEPCO	132KV Grid Station Rahim Yar Khan-I T-4 (31.5/40MVA)	14.05.2026	8:00	14:00	Six Monthly Maintenance	017130-Millat, 017128-Scarp-3, 017131-Iqbal Abad, 017122-Jinnah, 017106-Sheikh Waan, Basti Pursan	M. Akhlaq (Foreman) 0301-7643310
31	MEPCO	132KV Fazlipur / (P/Tr-T-2, 20/26 MVA)	14.05.2026 (Thursday)	07:30	13:30	For Six Monthly Maintenance	Hajipur (27401), City Fazlipur I (27403), Sahar Wala (27404), City Fazlipur II (27410), Adda Chiragh Shah (27408), Lal Gah (27411)	Mr. Zafar Iqbal (FM) 0319-9765543
32	MEPCO	132KV Fazlipur / (P/Tr-T-1, 10/13 MVA)	14.05.2026 (Thursday)	11:30	16:30	For Bus Coupler and Six Monthly Maintenance	Raikh Bagh Wala (27402), Mehray Wala (27407), Danish School (27409), Said Pur (27405), Hazrat Wala (27406)	Mr. Zafar Iqbal (FM) 0319-9765543
33	MEPCO	132KV Gujrat / T-3, 132/11.5KV, 10/13MVA PTF	Saturday, 16.05.26	08:30	14:30	For six monthly maintenance.	KD Qureshi (005202), Fossil Energy (005217), Mubartz Shahed (005218) & Lal Pir Power (Pvt) Ltd.	Mr. Mazhar Hussain (Fitter-I) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.

P=03


Sr. No.	Disco	Name of Grid Station / Transmission Lines & Name of Equipment	Date	Time		Purpose of Shut Down	Affected Area	Safety Inspector
				From	To			
34	MEPCO	132KV G/S Sadiq Abad 132KV Busbar-1 & 132KV Busbar-2	17.05.2026	6:00	12:00	Annual Maintenance of 132KV Busbar, Busbar Isolators and tightening of all Power Cables as well as Jumpers & Droppers.	132KV G/S Sadiq Abad 018118-Musa Nagar, 018126-Crown Motors, 018101-Bhong, 018106-Sanjhar Pur, 018124-New Satellite Town, 018112-Express-1, 018123-Model City, 018107-Nawaz Abad, 018130-Shan Floor Mill, 018131-Almal Bagh, 018132-Nawab Sadiq, 018133-Model Avenue, 018134-Ahmad Pur Lamma, 018135-Industrial State-2, 018137-Chaman, 018139-Noor Wala, 018138-Adam Sahaba, 018127-Industrial Estate-1, 018140-Unique City, 018136-Kander, 018141-Roshan Bhatt, 018108-Machi Goth, 018128-Nishar, 018103-Old Satellite Town, 018117-New Manthar, 018102-City, 018111-Azad Nursery, 018125-Khawaja Fareed, 018121-Meray Shah, 018129-Johar Town, 018113-Express-2, 018105-old manthar, 018120-Model town, 018119-Jinnah Town, 018122-AJPM, 018109-Feeder No.4, 132KV G/S Jamal Din Wali 053117-Chak Daba, 053125-J.K.DIary, 053114-Pacca Munna, 053116-Shahbaz Pur, 053121-Kacha Dingran, 053122-Kacha Mian Wali, 053101-City, 053124, D.Wali Sugar Mills, 053113-Bahodli Pur, 053111-Rajan Pur Kalam, 153127-Abbasia, 053112-Badli Sharif, 053110-Soon Mian, 053118-Kacha Razl, 053106-Rang Pur, 053126-Kot Karam Khan, 053128-Peer Abdul Malik, 053129-Kot Fageera	Rana Shahryar Khan LS-II 0319-9765610
35	MEPCO	132KV DG Khan-1/ (P/Tr-T-1, 31.5/40 MVA)	17.05.2026 (Sunday)	07:30	13:30	For Six Monthly Maintenance	GTM (3301), Industrial (3302), Quetta Road (3304), Gaddahi (3306), Chit Sirhani (3321), Wadoor (3322), Water supply (3324), Danish School (3325), Express (3326), New Defence Housing Scheme (3327), NDVHS Commercial (3331), Darti Meero (3332), P.G.S.H.S. (3333) D.G.H.S (3334)	Mr. Zafar Iqbal (FM) 0319-9765543
36	MEPCO	132KV Jattoi / T-2, 132/11KV, 20/26MVA PTF	Monday, 18.05.26	08:30	10:30	For safety purpose due to bus coupler	Balay Wala (007506), Hamzay Wali (007504), Siharli (007507), City Jattoi (007505) & City-II (007508)	Mr. Mazhar Hussain (Fitter-II) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
37	MEPCO	132KV Jattoi / T-1, 132/11KV, 10MVA PTF	Monday, 18.05.26	08:30	14:30	For six monthly maintenance.	Ram Pur (007503) & Permit (007501)	Mr. Mazhar Hussain (Fitter-II) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
38	MEPCO	132KV Grid Station Rahim Yar Khan-II T-1 (31.5/40MVA)	18.05.2026	8:00	14:00	Six Monthly Maintenance	076702-Scarp-8, 076701-Bahisht, 076706-Abu Dehbi, 076712-Sakhi Sarwar, 076711-Aziz Abad, 076709-Rehman Pur	M. Akhlaq (Foreman) 0301-7643310
39	MEPCO	132KV Kot Chutia/ (P/Tr-T-1, 20/26 MVA)	18.05.2026 (Monday)	07:30	12:30	For Six Monthly Maintenance	City Kot Chutia (054412), Industrial (054409), Thatha (054404), Mana Ahmdani (New)	Mr. Zafar Iqbal (FM) 0319-9765543
40	MEPCO	132KV Kot Chutia/ (P/Tr-T-3, 10/13 MVA)	18.05.2026 (Monday)	12:30	16:30	For Six Monthly Maintenance	Jhoke utra (054407) & Shero (054413).	Mr. Zafar Iqbal (FM) 0319-9765543
41	MEPCO	132KV Jattoi / T-2, 132/11KV, 20/26MVA PTF	Tuesday, 19.05.26	08:30	14:30	For six monthly maintenance.	Balay Wala (007506), Hamzay Wali (007504), Siharli (007507), City Jattoi (007505) & City-II (007508)	Mr. Mazhar Hussain (Fitter-II) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
42	MEPCO	132KV Grid Station Khanbela T-1 (20/26MVA)	19.05.2026	9:00	14:00	Six Monthly Maintenance	053308-Shedani Sharif, 053307-Malkani, 053310-Mud Ranha, 053312-Paca Latran, 053304-Jun Pur	M. Akhlaq (Foreman) 0301-7643310

Sl. No.	Place	Name of Grid Station / Transmission Lines & Name of Equipment	Date	Time		Purpose of Shut Down	Affected Area	Safety Inspector
				From	To			
43	MEPCO	132KV Grid Station Khanbela T-2 (31.5/40MVA)	19.05.2026	12:00	16:00	Six Monthly Maintenance	053302-Fateh Pur Kamal, 053303-Thul Hamza, 053301-Hamid Abad, 053309-City Khanbela, 053306-Haroon Abad, 053313-Fareed Abad.	M. Akhlaq (Foreman) 0301-7643310
44	MEPCO	132KV Kot Chutta/ (P/Tr, T-2, 20/26 MVA)	19.05.2026 (Tuesday)	07:30	13:30	For Six Monthly Maintenance	YTM (054402), Ghousabad (054410), Basti Jam (054411), Civil Line (054414).	Mr. Zafar Iqbal (FM) 0319-9765543
45	MEPCO	132KV Kot Chutta/ (P/Tr, T-1, 20/26 MVA)	19.05.2026 (Tuesday)	07:30	09:30	For Safety Purpose Due to Bus Coupler Maintenance	City Kot Chutta (054412), Industrial (054409), Thatha (054404), Mana Ahmdani (054415).	Mr. Zafar Iqbal (FM) 0319-9765543
46	MEPCO	132KV Jattoi / T-3, 132/11KV, 10/13MVA PTF	Wednesday, 20.05.26	08:30	14:30	For six monthly maintenance.	Jhugti Wala (007502)	Mr. Mazhar Hussain (Fitter-J) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
47	MEPCO	132KV Jampur / (P/Tr, T-1, 20/26 MVA)	20.05.2026 (Wednesday)	07:30	13:30	For Six Monthly Maintenance	Kodi Mughlan (74302), Khan Pur (74304), Basti Fauja (74305), THQ (74308) City Jampur (74307)	Mr. Zafar Iqbal (FM) 0319-9765543
48	MEPCO	132KV Jampur / (P/Tr, T-2, 20/26 MVA)	20.05.2026 (Wednesday)	11:30	16:30	For Bus Coupler and Six Monthly Maintenance	Indus (74301), Jakhra Chowk (74303), Bukhara (74306), Ashiq Abbas Shaheed (74309)	Mr. Zafar Iqbal (FM) 0319-9765543
49	MEPCO	132KV Khan Garh / T-2, 132/11KV, 13MVA PTF	Thursday, 21.05.26	08:30	10:30	For safety purpose due to maintenance of bus coupler	Khan Garh (076901) & Shams Abad (076903)	Mr. Mazhar Hussain (Fitter-J) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.
50	MEPCO	132KV Khan Garh / T-1, 132/11KV, 13MVA PTF	Thursday, 21.05.26	08:30	14:30	For six monthly maintenance.	Kamal Pur (076902), Gul Wala (076905) & City-II (076904)	Mr. Mazhar Hussain (Fitter-J) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654,
51	MEPCO	132KV Grid Station Rahim Yar Khan-I T-2 (31.5/40MVA)	21.05.2026	8:00	14:00	Six Monthly Maintenance	017126-AOM, 017105-Laever, 017112-Gulshan, 017107-Taranda, 017103-City, 017102-Industrial-I, 017125-Coke	M. Akhlaq (Foreman) 0301-7643310
52	MEPCO	132/66KV Jampur Dajal Road (P/Tr, T-1, 20/26 MVA, 132/11KV)	21.05.2026 (Thursday)	07:30	13:30	For Six Monthly Maintenance	City-II Jampur (029306), Industrial (029307), M/Pur (029303), Qadar abad (029302).	Mr. Zafar Iqbal (FM) 0319-9765543
53	MEPCO	132/66KV Jampur Dajal Road (P/Tr, T-2, 32.2 MVA, 132/66KV)	21.05.2026 (Thursday)	13:30	16:30	For Six Monthly Maintenance	56KV Dajal Dajal (054001), Harand (054002) & Noshaira (054003).	Mr. Zafar Iqbal (FM) 0319-9765543
54	MEPCO	132KV Khan Garh / T-2, 132/11KV, 13MVA PTF	Saturday, 23.05.26	08:30	14:30	For six monthly maintenance.	Khan Garh (076901) & Shams Abad (076903)	Mr. Mazhar Hussain (Fitter-J) Mobile # 0319-9765534 & Mr. Muhammad Mohsin (ASSA / Test Insp.) Mobile # 0319-9759654, P&I S/Divn. MFG to carry out relevant protection testing.

P=05

Sl. No.	Dise	Name of Grid Station / Transmission Lines & Name of Equipment	Date	Time		Purpose of Shut Down	Affected Area	Safety Inspector
				From	To			
55	MEPCO	66KV Dajal/ (P/Tr, T-1, 10/13 MVA)	23.05.2026 (Saturday)	08:30	12:30	For Six Monthly Maintenance	Dajal (S4001), Harand (S4002)	Mr. Zafar Iqbal (FM) 0319-9765543
56	MEPCO	66KV Dajal/ (P/Tr, T-2, 6.3 MVA)	23.05.2026 (Saturday)	12:30	16:30	For Six Monthly Maintenance	Noshera (S4003)	Mr. Zafar Iqbal (FM) 0319-9765543
57	MEPCO	132KV Grid Station Liaquat Pur T-1 (20/26MVA)	24.05.2026	9:00	14:00	Six Monthly Maintenance	012207-Allah Abad, 012204-K.M.Khan, 012206-City, 012210-Taranda, 012214-Hakeem Abad	M. Akhlaq (Foreman) 0301-7643310
58	MEPCO	132KV Grid Station Liaquat Pur T-2 (20/26MVA)	24.05.2026	12:00	16:00	Six Monthly Maintenance	012211-Kachi Mandi, 012203-Saline Zone, 012208-Rais Pathan, 012209-Maitla, 012212-Abbasia	M. Akhlaq (Foreman) 0301-7643310

F-06