

SHUT DOWNS ON 132KV TRANSMISSION LINES / GRID STATIONS (AREA EFFECTED)
I.R.O GSO CIRCLE MEPCO SAHIVAL FOR 05/2026

| Sr. No. | Disco | Name of Grid Station / Name of Equipment | Date | Day | Time | | Purpose of Shut Down | Affected Area | Safety Supervisor |
|---------|-------|--|----------|-----------|------|-------|--|--|---|
| | | | | | From | To | | | |
| 1 | MEPCO | 132KV Burewala / 132/11KV, 31.5/40MVA P/TF T-1 | 06.05.26 | Wednesday | 8.00 | 16.00 | To replace the problematic AREVA make 11KV Bus Coupler with PEL make healthy one | 11KV O/G City-5 (002021), Mana More (002030), Hameed Shabheed (002026), City-6 (002022), City-2 (002002), Shabbir Shabheed (002023), Machi Wali (00209), Multan Road (002031) <u>(08-No Feeders)</u> | Muhammad Akram FM Cell # 0319-9765770 |
| 2 | MEPCO | 132KV Burewala / 132/11KV, 31.5/40MVA P/TF T-3 | 06.05.26 | Wednesday | 8.00 | 16.00 | To remove the deteriorated spare 11KV panel from panel board & Annual maintenance / protection testing of 11KV Panel board | 11KV O/G City-3 (002003), Masoom Shah (002017), City-4 (002004), Mujahid Colony (002020), Gaggoo (002007), Zahoor Nager (002016), Ghallian Mandi (002025), Sabar Raza Shabheed (002027) <u>(08-No Feeders)</u> | Muhammad Akram FM Cell # 0319-9765770 |
| 3 | MEPCO | 500/220/132KV Yousafwala / 132/11KV, 20/26MVA P/TF T-8 | 07.05.26 | Thursday | 8.00 | 16.00 | To tighten the jumpers and Cleaning of disc insulators of sensitive locations | 11KV O/G Ghous Pak (098911), Shaifu Shabheed (098912), Medina Colony (098906), B&R (098901), Fetha Shah (0986908), Dewan Sahib (098907), Habib Colony (098910), Khair Wala (098909), Al-Azan City (N/A) <u>(09-No Feeders Burewala Old) 11KV O/G Sadat (053709), Umar Pur (053703), Al-Abas (053705), Murad Ali (053707) Jamliarya (053706), Sahuka (053702), Saidara (053704), Sarwar Shah (053708), Hajj Sher (053701), Jodhaka (053710), Subhan Shah (053711) & Yousaf Shabheed (12-No Feeders)</u> | Altar Hussain, LS-I Cell # 0319-9765744 |
| 4 | MEPCO | 132KV Burewala-Burewala Old T/Line, controlled by 132KV CB BRW-3-BWO-1 | 07.05.26 | Thursday | 7.00 | 10.00 | To setright the Red phase dead end Jumper at tower No. 02 | Whole area of 132KV G/S Melecod Guni 032705 MGuni, 054507 M.S.G Road, 032704 M.Abad-II, 032706 Anwar Shabheed, 032707 Al-Mustahiq, 032702 City, 032701 Annuka, 032703 M/Abbad/1 & 032708 Head Sulemanki feeders | Naveed Hussain (AET Bahawal Nagar) 0319-9765643 |
| 5 | MEPCO | 132KV Minchin Abad-Melecod Guni T/Line controlled by 132KV CB MNA-2 -MLG-1 | 07.05.26 | Thursday | 7:00 | 12:00 | Tightening the jumpers and Cleaning of disc insulators of sensitive locations | 11KV O/G, Ailama Iqbal (58408), Ghalla Mandi (58410), Ganj Shaker (58409), Colony (58404), Auxilar-6 <u>(05-No feeders)</u> | Muhammad Akram FM Cell # 0319-9765770 |
| 6 | MEPCO | 500/220/132KV Yousafwala / 132/11KV, 20/26MVA P/TF T-7 | 11.05.26 | Monday | 8.00 | 14.00 | Annual maintenance / protection testing of 11KV Panel board | Whole area of 132KV G/S Marrot 060601 Marrot-I, 060603 Mansoor, 060604 Cholistan, 060605 Zia, 060606 Rohi, 060607 Sarder, 060608 Chappu & 060609 Meer Garh feeders | Muhammad Akram FM Cell # 0319-9765770 |
| 7 | MEPCO | 132KV Fort Abbas-Marrot T/Line controlled by 132KV CB FTA-2 -MRT-2 | 11.05.26 | Monday | 7:00 | 12:00 | Tightening the jumpers and Cleaning of disc insulators of sensitive locations | 11KV O/G, Jahan Khan (019603), Jaffer Shah (019609) <u>(02-No Feeders)</u> | Muhammad Akram FM Cell # 0319-9765770 |
| 8 | MEPCO | 132KV Noor Pur/ 132/11KV, 10/13MVA P/TF T-3 | 12.05.26 | Tuesday | 8.00 | 14.00 | To connect the 11KV incoming panel with panel board T-3 for use as 11KV Bus Coupler | 11KV O/G Ulfat Shabheed, Asghar Hussain (134001), Siddique Shah <u>(03-No feeders)</u> | Muhammad Akram FM Cell # 0319-9765770 |
| 9 | MEPCO | 132KV Pakpattan-II/ 132/11KV, 20/26MVA P/TF T-1 | 13.05.26 | Wednesday | 8.30 | 12.30 | To connect Power Cable between auxiliary transformer to 11KV Bus Coupler / Change over | 11KV O/G Rehmat Shabheed (134002), Nazam Shah (NA), Adda Chawant, Pakka Sadhar <u>(04-No feeders)</u> | Muhammad Akram FM Cell # 0319-9765770 |
| 10 | MEPCO | 132KV Pakpattan-II/ 132/11KV, 31.5/40MVA P/TF T-2 | 13.05.26 | Wednesday | 8.30 | 12.30 | To connect Power Cable between auxiliary transformer to 11KV Bus Coupler / Change over | 11KV O/G J.T.M (013313), Q.T.M (013307), M.T.M (013314) <u>(03-No feeders)</u> | Muhammad Akram FM Cell # 0319-9765770 |
| 11 | MEPCO | 132KV Mian Channu / 132/11KV, 20/26MVA P/TF T-4 | 14.05.26 | Thursday | 8.30 | 14.30 | Annual maintenance / protection testing | | Muhammad Akram FM Cell # 0319-9765770 |

Boi

| Sr. No. | Disco | Name of Grid Station / Name of Equipment | Date | Day | Time | | Purpose of Shut Down | Affected Area | Safety Supervisor |
|---------|-------|--|----------|----------|------|-------|---|---|---|
| | | | | | From | To | | | |
| 12 | MEPCO | 132 KV Bahawal Nagar II-Minchin Abad T/L controlled by 132 KV C.B BNR-2 & MNA-1 | 14.05.26 | Thursday | 7:00 | 12:00 | Tightening the jumpers and Cleaning of disc insulators of sensitive locations | Whole area of 132KV G/S Minchin Abad & Mecleod Gunj 054504 Fidal Shah, 054502 City Minchin Abad, 054505 Railway Road, 054506 Farooq Shahed, 054503 Mehmood, 054501 PPN Road, 032705 M/Gunj, 054507 M.S.G Road, 032704 M.Abad-II, 032706 Anwar Shahed, 032707 AL-Mushdaq, 032702 City, 032701 Amruka, 032703 M/Abad/1 & 032708 Head Sulamanki feeders | Naveed Hussain (AET Bahawal Nagar) 0319-9765643 |
| 13 | MEPCO | 132KV Fort Abbas-Marot T/L controlled by 132KV CB FTA-2 - MRT-2 | 18.05.26 | Monday | 7:00 | 12:00 | Tightening the jumpers and Cleaning of disc insulators of sensitive locations | Whole area of 132KV G/S Marot. 060601 Marot-I, 060603 Mansoor, 060604 Cholistan, 060605 Zia, 060606 Rohi, 060607 Sarder, 060608 Chappu & 060609 Meer Garh feeders | Naveed Hussain (AET Bahawal Nagar) 0319-9765643 |
| 14 | MEPCO | 132KV Minchin Abad-Mecleod Gunj T/L controlled by 132KV CB MNA-2 - MLG-1 | 21.05.26 | Thursday | 7:00 | 12:00 | Tightening the jumpers and Cleaning of disc insulators of sensitive locations | Whole area of 132KV G/S Meceleod Gunj 032705 M/Gunj, 054507 M.S.G Road, 032704 M.Abad-II, 032706 Anwar Shahed, 032707 AL-Mushdaq, 032702 City, 032701 Amruka, 032703 M/Abad/1 & 032708 Head Sulamanki feeders | Naveed Hussain (AET Bahawal Nagar) 0319-9765643 |

Red W