



MULTAN ELECTRIC POWER COMPANY (MEPCO)

Tel : 061-6305545
Fax: 061-6305546
No. : 18435-451

Office of
The Chief Executive
Dated: 19/05/2026.

Superintending Engr: (GSO)
MEPCO Circle Sahiwal.

Subject: APPROVAL OF SHUT DOWN.

Ref. SE GSO MEPCO Circle Sahiwal letter No. 2819-25 dated 12.05.2026.

The shut down as required by you is hereby approved subject to publication in the important news add papers as well as prior information to all important / dedicated consumers duly confirmed in writing and their concurrence. In addition the announcement through loudspeakers of Mosques be made for the information of General Public. **It is also requested to direct SSO Incharge of concerned Grid Station to implement the revised load shedding schedule strictly as directed by worthy GM (Op) MEPCO HQ Multan.**

Sr No	Disco	Namd of Grid Station / Name of Equipment	Date & Time	Purpose Of Shutdown	Effected Area
1	MEPCO	250MVA Auto T/F T-3	20.05.2026 08:00 To 16:00	For Instalation of 11kv Tertiary Bus bar with Raychem Tube (23kv)	Arifwala 04MW Qabula 03MW Kameer 03MW Sahiwal Old 04MW Harappa 03MW Sahiwal New 03MW Qadirabad 03MW Noor Pur 03MW Pakpattan 04MW (Load Shedding 30MW is required of following 132KV G/S)
2		160MVA Auto T/F T-4	21.05.2026 08:00 To 16:00	For Replacement of MDU of OLTC with New One	

NOTE. M. Mr. Ajmal Iqbal FM has been declared as Safety Supervisor for this Shutdown as told by XEN GC Divn GSC MEPCO.

It must be ensured that the timings of the shutdown are observed strictly & the electricity supply is restored accordingly.

This issues with the approval of Chief Engineer (O&M) Distn: MEPCO Multan.

Note:- The compensation schedule must be implemented in true spirit as per directions of worthy Chief Engineer (Op) MEPCO HQ Multan.

DA/Schedule of shut down.

C.C.

- 1- General Manager (Op) MEPCO HQ Multan for information along with Compensation schedule in load shedding programme please.
- 2- Chief Engineer (O&M) Distn: for information as desired please.
- 3- CE NPCC Islamabad / Director RCC Jamshoro for information please.
- 4- S.E. (OP) MEPCO Sahiwal w.r. to his letter No. 8357-60 dated 18.05.2026 with Compensation schedule in load shedding programme as received from your office with the request to implement the schedule.
- 5- Director (IT) MEPCO Multan for necessary action & uploading on website, please.
- 6- XEN (Op) MEPCO RY Khan Div with the advise to carry out Maintenance works on the said feeders during this approved shut down as desired by Competent Authority.
- 7- Dy: Manager M.P.C.C MEPCO Multan along with Compensation schedule in load shedding programme for Implementation & also to inform PITC & load on Roshan Pakistan app. pl.
- 8- Dy: Manager R.C Cell for information and necessary action.
- 9- Addl: Manager (P.R) MEPCO H/Q Multan with the advice to arrange Publication in newspapers & announcement through Electronic media & send the press cutting of above shut down.
- 10- Mr.Ameer Hamza SSO-I/ Safety Inspector (HSE) with the directions to monitor the above shut down and ensure the Implementantion of all Safety measures in true letter & Spirit as per MEPCO SOP.

Dy: Manager (O&M) Distn:
MEPCO Ltd. Multan