



MULTAN ELECTRIC POWER COMPANY (MEPCO)

Tel : 061-6305545
 Fax: 061-6305546
 No. : 19543-531

Office of
 The Chief Executive
 Dated: 23/06/2026.

**Superintending Engr: (GSO)
 MEPCO Circle Multan.**

Subject: APPROVAL OF SHUT DOWN.

Ref. SE GSO MEPCO Circle Multan letter No. 7104-11 dated 22.06.2026.

The shut down as required by you is hereby approved subject to publication in the important news add papers as well as prior information to all important / dedicated consumers duly confirmed in writing and their concurrence. In addition the announcement through loudspeakers of Mosques be made for the information of General Public. **It is also requested to direct SSO Incharge of concerned Grid Station to implement the revised load shedding schedule strictly as directed by worthy GM (Op) MEPCO HQ Multan.**

Sr No	Disco	Namd of Grid Station / Name of Equipment	Date & Time	Purpose Of Shutdown	Effected Area
1	MEPCO	132KV Kot Addu / T-4, 132/11KV, 31.5/40MVA PTF	28.06.2026 07:30 To 09:30	For safety purpose due to maintenance of bus coupler	Kot Addu City (011202), D.D.Panah-I (011201), TWF-10 (011215), College Road (011219) & T.P.Link-8+9 (011204)
2		132KV Kot Addu / T-3, 132/11KV, 20/26MVA PTF	28.06.2026 07:30 To 12:30	For six monthly maintenance	TWF-4 (011208), TWF-1(011205), Sanawan (011203), TWF-7 (011211) & TWF-3 (011207)
3		132KV Kot Addu / T-4, 132/11KV, 31.5/40MVA PTF	28.06.2026 12:30 To 17:30	For six monthly maintenance.	Kot Addu City (011202), D.D.Panah-I (011201), TWF-10 (011215), College Road (011219) & T.P.Link-8+9 (011204)

NOTE.M.Yahya (Fitter-I) No.0333-6732621 has been declared as Safety Supervisor for this Shutdown as told by SE GSO Multan.

It must be ensured that the timings of the shutdown are observed strictly & the electricity supply is restored accordingly.

This issues with the approval of Chief Engineer (O&M) Distn: MEPCO Multan.

Note:- The compensation schedule must be implemented in true spirit as per directions of worthy Chief Engineer (Op) MEPCO HQ Multan.

DA/Schedule of shut down.

C.C.

**Dy: Manager (O&M) Distn:
 MEPCO Ltd. Multan**

- 1- General Manager (Op) MEPCO HQ Multan for information along with Compensation schedule in load shedding programme please.
- 2- Chief Engineer (O&M) Distn: for information as desired please.
- 3- CE NPCC Islamabad / Director RCC Jamshoro for information please.
- 4- S.E. (OP) MEPCO M/Garh v.r. to his letter No. 12692-95 dated 22.06.2026 with Compensation schedule in load shedding programme as received from your office with the request to implement the schedule.
- 5- Director (IT) MEPCO Multan for necessary action & uploading on website, please.
- 6- XEN (Op) MEPCO Kot addu Div with the advise to carry out Maintenance works on the said feeders during this approved shut down as desired by Competent Authority.
- 7- Dy: Manager M.P.C.C MEPCO Multan along with Compensation schedule in load shedding programme for Implementation & also to inform PITC & load on Roshan Pakistan app. pl.
- 8- Dy: Manager R.C Cell for information and necessary action.
- 9- Addl: Manager (P.R) MEPCO H/Q Multan with the advice to arrange Publication in newspapers & announcement through Electronic media & send the press cutting of above shut down.
- 10- Mr.Ameer Hamza SSO-I/ Safety Inspector (HSE) with the directions to monitor the above shut down and ensure the Implementantion of all Safety measures in true letter & Spirit as per MEPCO SOP.