

Tel : 061-6305545

Fax: 061-6305546

No. : 313-24 / 1

Office of

The Chief Executive

Dated: 12/07/2026.

Superintending Engr: (GSO)

MEPCO Circle Sahiwal.

Subject: APPROVAL OF SHUT DOWN.

Ref. SE GSO MEPCO Circle Sahiwal letter No. 3747-55 dated 07.07.2026.

The enclosed shut downs as required by you is hereby approved subject to publication in the important newspapers as well as prior information to all important / dedicated consumers duly confirmed in writing and their concurrence. In addition the announcement through loudspeakers of Mosques be made for the information of General Public. *It is also requested to direct SSO Incharge of concerned Grid Station to implement the revised load shedding schedule strictly as directed by worthy GM (Op) MEPCO HQ Multan.*

NOTE: All Safety Supervisor Names and Nos enclosed / Atteched all Copies of this shut downs as told by SE GSO Sahiwal.

It must be ensured that the timings of the shutdown are observed strictly & the electricity supply be restored accordingly.

This issue with the approval of Chief Engineer (O&M) Distn. MEPCO Multan.

Note:- The compensation schedule must be implemented in true spirit as per directions of worthy Chief Engineer (Op) MEPCO HQ Multan.

DA/Schedule of shut down.

P=01

C.C.

**Dy: Manager (O&M) Distn:
MEPCO Ltd. Multan**

- 1- General Manager (Op) MEPCO HQ Multan for information along with Compensation schedule in load shedding programme please.
- 2- Chief Engineer (O&M) Distn: for information as desired please.
- 3- CE NPCC Islamabad / Director RCC Jamshoro for information please.
- 4- S.E. (OP) MEPCO MEPCO Sahiwal, B/Nagar & Khanewal w.r. to their letter No. 11613-14 Dated 09.07.2026 No.11915-24 Dated 08.07.2026 & No.12719-26 Dated 10.07.2026 with Compensation schedule in Load shedding programme as received from your office with the request to implement the schedule.
- 5- Director (IT) MEPCO Multan for necessary action & uploading on website, please.
- 6- Dy.Manager (O&M) T&G for information as desired please.
- 7- All XENs under (Op) Circles Sahiwal, B/Nagar & Khanewal MEPCO Div with the advise to carry out Maintenance works on the said feeders during this approved shut down as desired by Competent Authority.
- 8- Dy: Manager M.P.C.C MEPCO Multan along with Compensation schedule in load shedding programme for Implementation & also to inform PIRC & load on Roshan Pakistan app. pl.
- 9- Dy: Manager R.C Cell for information and necessary action.
- 10- Addl: Manager (P.R) MEPCO H/Q Multan with the advice to arrange Publication in newspapers & announcement through Electronic media & send the press cutting of above shut down.
- 11- Mr.Ameer Hamza SSO-I/ Safety Inspector (HSE) with the directions to monitor the above shut down and ensure the Implementantion of all Safety measures in true letter & Spirit as per MEPCO SOP.

SHUT DOWNS ON GRID STATIONS TO ATTEND THE THERMOVISION POINTS AND REPLACEMENT/REMOVAL OF PANELS (AREA EFFECTED)

I.R.O GSO CIRCLE MEPCO SAHIWAL FOR 07/2026

Sr. No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
1	MEPCO	132KV Arifwala / 132/11KV, 31.5/40MVA P/TF T-1	14.07.26	Tuesday	6.00	8.00	To attend the thermovision points of L.V Bushing and tightening the 1000MCM Power Cables.	No area will be effected as the supply of P/TF T-1 will be restored through 11KV Bus coupler. But 10 MW load shedding will be required.	Muhammad Akram FM Cell # 0319-9765770
2	MEPCO	132KV Arifwala / 132/11KV, 31.5/40MVA P/TF T-2	14.07.26	Tuesday	8.00	10.00	To attend the thermovision points of L.V Bushing and tightening the 1000MCM Power Cables.	No area will be effected as the supply of P/TF T-2 will be restored through 11KV Bus coupler. But 10 MW load shedding will be required.	Muhammad Akram FM Cell # 0319-9765770
3	MEPCO	132KV Arifwala / 132/11KV, 31.5/40MVA P/TF T-3	14.07.26	Tuesday	10.00	12.00	To attend the thermovision points of L.V Bushing and tightening the 1000MCM Power Cables.	No area will be effected as the supply of P/TF T-3 will be restored through 11KV Bus coupler. But 05 MW load shedding will be required.	Muhammad Akram FM Cell # 0319-9765770
4	MEPCO	132KV Bahawal Nagar/132KV Bus Bar controlling 132KV C.Bs BWN-1, BWN-2, BWN-5, BWN-6	14.07.26	Tuesday	5.30	8.30	To attend the thermovision point on blue phase of 132KV isolators 5-1 & 8-1 towards bus bar side	Whole area of 132KV G/S Bahawal Nagar (11KV/000904 QT Mill, 000905 Scarp-D, 000903 City, 000916 Din Pur Shareef, 000911 Nizam Pura, 000906 Malik Pura, 000907 Scarp FV, 000909 Jail Wala, 000902 Q/Road, 000908 City-II, 000910 Cant, 000912 Hospital, 000921 Qaisar Shaeed, 000919 New City Housing Scheme, 000915 Dist. Jail, 000901 Canal, 000917 Adda Khiraj Pura, 000918 Nawab Sadq, 000920 Ibraheem Shaeed, 000922 Star City, 000923 Ahmad Hasan Rice Mills feeders)	Obaid Ullah (AEM Vehan) 0319-9765641
5	MEPCO	132KV Arifwala / 132/11KV, 31.5/40MVA P/TF T-1	15.07.26	Wednesday	7.00	11.00	To replace the problematic panel of 11KV Outgoing Al-Madhi feeder with new one.	11KV O/G Old Factory (000502), Qalander Shah (000523), City (000511), Magger (000504), Kalyana (000503), Al-Madhi (000513), (06-No Feeders)	Muhammad Akram FM Cell # 0319-9765770
6	MEPCO	132KV Sahiwal Old/ 132KV Bus Bar No-1 & 2, controlled by 132KV CB's SHW-1, SHW-2, SHW-3, SHW-4, SHW-5, SHW-6 & SHW-7 along with T/Lines	19.07.265	Sunday	5.00	9.00	To replace the 02-Nos. damaged conductor strands of jumpers of SHW-7 line bay (Bus Bar Side) with new ones	11KV O/G Royal Palm (018330), Kashmeer Adhal (018317), Lather Co-Ordinator (018326), M.A Foods (018327), City-1 (018303), Arif Road (018334), Bodd Dhakoo (018322), Khuja Arif (018323), Multan Road (018307), P.G.H.S (018336), Industrial Estate (018315), Civil Line (018304), Aywa City-1 (018341), Aywa City-2	Muhammad Akram FM Cell # 0319-9765770
7	MEPCO	132KV Bati Banglow/ 132/11KV, 10/13MVA P/TF T-2	22.07.26	Tuesday	9.00	13.00	To remove 01-No. spare 11KV outgoing panel from T-2 panel board.	11KV O/G Fareed Pur (109305) & Kot Gohar Muhammad (109304) (02-No Feeders)	Muhammad Akram FM Cell # 0319-9765770