

Tel : 061-6305545
Fax: 061-6305546
No. : 1147-56 /

Office of
The Chief Executive
Dated: 13/08/2026.

Superintending Engr: (GSO)
MEPCO Circle Multan.

Subject: APPROVAL OF SHUT DOWN.

Ref. SE GSO MEPCO Circle Multan letter No. 8950-56 dated 12.08.2026.

The shut down is as required by you is hereby approved with the condition that electricity of any consumer would not be interrupted & subject to publication in the important newspapers as well as prior information to all important / dedicated consumers duly confirmed in writing and their concurrence. In addition the announcement through loudspeakers of Mosques be made for the information of General Public. It is also requested to direct SSO Incharge of concerned Grid Station to implement the revised load shedding schedule strictly as directed by worthy GM (OP) MEPCO HQ Multan.

Sr No	Disco	Namd of Grid Station / Name of Equipment	Date & Time	Purpose Of Shutdown	Effected Area
1	MEPCO	132KV Grid Station Vehari Road Multan	20.08.2026 08:00Hrs To 16:00Hrs	For replacement of too old problematic RP-4 and CP-50 panels of TR-2	XEN SS&T MTN vide letter No 6335-36 dated 11.08.2026 No area will be affected as the supply of 11KV feeders of the said P/TF will be restored through 11KV Bus Coupler from TR-1 Power Transformer 04MW to 05MW Force Load Management will be expected between 14:00Hrs to 16:00Hrs.
NOTE.Mr.Waheed (TI) P&I0303 7212342 will be safety inspector has been declared as Safety Supervisor for Implementing the all Safety Measure as per MEPCO SOP for this Shutdown, as informed by SE GSO Multan.					

It must be ensured that the timings of the shutdown are observed strictly & the electricity supply be restored accordingly.

This issues with the approval of Chief Engineer (O&M) Distn: MEPCO Multan.


fr. DY.Manager (O&M) Distn:
MEPCO Ltd. Multan

C.C.

- 1- General Manager (Op) MEPCO HQ Multan for information please.
- 2- Chief Engineer (O&M) Distn: for information as desired please.
- 3- Chief Engineer (O&M) T&G for information as desired please.
- 4- Chief Engineer NPCC Islamabad / Director RCC Jamshoro for information please.
- 5- S.E. (OP) MEPCO Multan for information.
- 6- Dy.Manager (O&M) T&G for information as desired please.
- 7- Dy: Manager (PDC) MEPCO Multan for Implementation Please.
- 8- Addl:Manager (PR) MEPCO Multan.
- 9- Mr.Ameer Hamza SSO-I/ Safety Inspector (HSE) with the directions to monitor the above shut down and ensure the Implementantion of all Safety measures in true letter & Spirit as per MEPCO SOP.

Tel : 061-6305545

Fax : 061-6305546

No. : 1935-46 /

Office of

The Chief Executive

Dated: 13/08/2026.

Superintending Engr: (GSO)MEPCO Circle Multan.

Subject: APPROVAL OF SHUT DOWN.

Ref. SE GSO MEPCO Circle Multan letter No. 8437-43 dated 30.07.2026.

The enclosed shut downs as required by you is hereby approved subject to publication in the important newspapers as well as prior information to all important / dedicated consumers duly confirmed in writing and their concurrence. In addition the announcement through loudspeakers of Mosques be made for the information of General Public. *It is also requested to direct SSO Incharge of concerned Grid Station to implement the revised load shedding schedule strictly as directed by worthy GM (Op) MEPCO HQ Multan.*


Sr No	Disco	Namd of Grid Station / Name of Equipment	Date & Time	Purpose Of Shutdown	Effected Area
1	MEPCO	132KV G/S Khanpur T-3 (31.5/40MVA)	16.08.2026 08:00 To 12:00 (04 Hrs)	To install new panel for load shifting/ balancing	010213-Jinnah010217-Fareedi 010202-City 010215-M.A.Bachaya 010203-Bagho Bahar 010205-Zahir Peer
2		132KV G/S Rahim Yar Khan-1st T-2 (31.5/40MVA)	18.08.2026 07:00 To 11:00 (04 Hrs)	To Replace old/problematic panel of 11KV O/G Tarandah Feeder	017126-AOTM017105-Lever 017112-Gulshan017107-Taranda 017103-City017102-Industrial-I 017125-Coke 017139-M.Salim Shaheed
3		132KV G/S Rahim Yar Khan-2nd T-1 (31.5/40MVA)	20.08.2026 07:00 To 11:00 (04 Hrs)	To Replace old/problematic panel of 11KV O/G Bahishti Feeder	076702-Scarp-8076701-Bahishti 076706-Abu Dehbi 076712-Sakhi Sarwar 076711-Aziz Abad 076709-Rehman Pur
4		132KV G/S Rahim Yar Khan-2nd T-2 (20/26MVA)	23.08.2026 07:00 To 11:00 (04 Hrs)	To Replace old/problematic panel of 11KV O/G Scarp-9 Feeder	076713-Quaid Azam 076705-Allama Iqbal 076703-Scarp-9 076722-K.F.University076708-Surian 076710-Al-Khair

It must be ensured that the timings of the shutdown are observed strictly & the electricity supply be restored accordingly.

This issue with the approval of Chief Engineer (O&M) Distn. MEPCO Multan.

Note:- The compensation schedule must be implemented in true spirit as per directions of worthy Chief Engineer (Op) MEPCO HQ Multan.

DA/Schedule of shut down.


Dy: Manager (O&M) Distn:
MEPCO Ltd. Multan

C.C.

- General Manager (Op) MEPCO HQ Multan for information along with Compensation schedule in load shedding programme please.
- Chief Engineer (O&M) Distn: for information as desired please.
- CE NPCC Islamabad / Director RCC Jamshoro for information please.
- S.E. (OP) MEPCO MEPCO RY Khan w.r. to their letter No. 4437-42 dated 12.08.2026 with Compensation schedule in Load shedding programme as received from your office with the request to implement the schedule.
- Director (IT) MEPCO Multan for necessary action & uploading on website, please.
- Dy.Manager (O&M) T&G for information as desired please.
- XENs (Op) division RY Khan & Khan pur MEPCO Div with the advise to carry out Maintenance works on the said feeders during this approved shut down as desired by Competent Authority.
- Dy: Manager M.P.C.C MEPCO Multan along with Compensation schedule in load shedding programme for Implementation & also to inform PITC & load on Roshan Pakistan app. pl.
- Dy: Manager R.C Cell for information and necessary action.
- Addl: Manager (P.R) MEPCO H/Q Multan with the advice to arrange Publication in newspapers & announcement through Electronic media & send the press cutting of above shut down.
- Mr.Ameer Hamza SSO-I/ Safety Inspector (HSE) with the directions to monitor the above shut down and ensure the Implemantation of all Safety measures in true letter & Spirit as per MEPCO SOP.