

Amendment No 2

Installation, Testing, Commissioning and Civil Works for Rehabilitation of 46 Nos. 11kV Feeders Lot Wise under World Bank EDEIP Loan Project.

RFB No: PK-MEPCO-562889-CW-RFB

In accordance with Section ITB 8.1, Amendment-2 has been made in Bidding Documents for subject procurement which shall be read and construed as an integral part of Bid document and shall take precedence in case of any conflict(s)/ ambiguity(s) amongst this document and other provisions.

1. SECTION 2 –BID DATA SHEET

Para ITB 22.1 & ITB 25.1:

The deadline for submission of bids and the date and time for opening of bids specified under the above referenced paras are hereby extended and revised as “27 October 2026 at 11:00 AM”.

2. Section 3- Qualification and Evaluation Criteria

4.2(a)-Specific Construction & Contract Management Experience

The relevant clause is amended as:

"A minimum number of similar contracts specified below for construction of Distribution or Transmission line works that have been satisfactorily completed as a prime contractor, joint venture member , management contractor or Subcontractor between 1st January 2015 and bid submission deadline:

Lot I: Minimum Five (05) contracts with aggregate value PKR 82 million or equivalent;

Lot II: Minimum Five (05) contracts with aggregate value PKR 74 million or equivalent;

Lot III: Minimum Five (05) contracts with aggregate value PKR 60 million or equivalent;

Lot IV: Minimum Five (05) contracts with aggregate value PKR 86 million or equivalent;

Lot V: Minimum Five (05) contracts with aggregate value PKR 76 million or equivalent;

For Multiple Lots

Requirement will be the aggregate for the Lots against which Bid is submitted.

The similarity of the contracts shall be based on the following: Section VII, Scope of Works"



3. Section 3- Qualification and Evaluation Criteria

4.2(b)- Specific Construction & Contract Management Experience

The relevant clause is amended as:

“For the above and any other contracts that have been successfully completed as prime contractor, joint venture member, or Subcontractor between 1st January 2015 and Application submission deadline, a minimum construction experience in the following key activities successfully completed:

- i) Erection of LT/HT PCC or Steel Structure Poles
- ii) Stringing of conductor (11Kv or above voltage)”

4. Section IV- Bidding Forms

Bill of Quantities- A. Preamble

Lot-IV in para 1 of above section is amended as:

“Installation, Testing, Commissioning and Civil Works of 6 Nos. Feeders of Multan Circle, and 4 Nos. Feeders of Muzaffargarh Circle.”

5. Section IV- Bidding Forms

Bill of Quantities- A. Preamble

The relevant section is amended to include the following additional requirement.

The Contractors of Lot-1, Lot-2, Lot-3, Lot-4 and Lot-5 will lift PCC poles from following pole plants in accordance with their requirement of the respective lot:

PCC Poles	Qty (No.)	Pole Plant Address
45 ft	1646	Unze Trading (Pvt) Ltd, 35 Sahianwala FIEDMC Faisalabad.
45 ft	1646	Bliss Construction (Pvt) Ltd, Chak# 3/11, Thal, 18- Hazari Bhakkar Road.
31 ft	26	Bliss Construction (Pvt) Ltd, Chak# 3/11, Thal, 18- Hazari Bhakkar Road.
36 ft	2808	RK Constructors(Pvt)Ltd, 6-KM Lahore Sargodha Road Thatha Kheru Mtmal, Pindi Bhatian District hafizabad.
36 ft	2808	Junaid Pvt Ltd, 25 km ,Multan Road Maraka ,Lahore
36 ft	2808	Rajpoot Concrete(Pvt) Ltd ,1 KM, Main G.T Road, Sadhoke, District Gujranwala



6. Section VII- Works Requirement

Scope of Work

The relevant section is amended to include the following additional requirement.

“Provision and installation of a proper earthing system for Poles, including a drilled bore electrode, shall be mandatory. The earthing system shall achieve an earth resistance value of less than 5 ohms.”

7. Section VII- Works Requirement

The relevant section is amended to include the following additional requirement.

“Material will be issued through Line superintendent (RRE)MEPCO to the contractor on weekly basis or feeder wise or other approach as agreed by employer and contractor at the time of contract award. After handing over of material by the LS, the contractor will arrange temporary storage of material and contractor will be responsible for safe custody, temporary storage and security of the issued material .The dismantled material will be returned by the contractor to Concerned Regional Stores through relevant offices of RRE formation.”

Other terms and conditions shall remain same


Chief Engineer (Development) PMU
MEPCO Multan